

Our ref: WK201114797/EP000000022
Please ask for: Daniel Ward
Direct Dial: 01473 433079
Email: daniel.ward@ipswich.gov.uk



Ms C. Roberts
ASDA Ltd
Goddard Road
Whitehouse Industrial Estate
Ipswich IP1 5PD

Grafton House
15-17 Russell Road
Ipswich Suffolk
IP1 2DE

www.ipswich.gov.uk

15th May 2012

Dear Ms Roberts

**The Pollution Prevention and Control Act 1999
The Environmental Permitting Regulations (England and Wales) 2007
LAPPC Permit Ref No: PS9/VPA/01/10**

Following our inspection of the petrol station on Thursday 10th April the permit was satisfactory complied with, subject to the following;

It is necessary that you provide us with the information and documentation that shows you have carried out the requirements of condition 28 of your permit;

- Petrol delivery and vapour recovery systems for vehicle petrol tanks shall be tested for;
- Vapour containment integrity at least once every three years, and effectiveness of the vapour recovery system at least every three years where an automatic monitoring system.

Please provide a vapour recovery certificate to show the efficiency of the vapour recovery system and other relevant documentation that shows the upkeep of maintenance.

The requested information can be sent by email or posted to;

Environmental Protection Services
Ipswich Borough
Grafton House
15-17 Russell Road
Ipswich
IP1 2DE

Please contact me if you wish to discuss this matter
Yours Sincerely,

Daniel Ward
Student Environmental Health Officer

Cc ASDA Stores Ltd, ASDA House, Southbank, Great Wilson Street, Leeds, LS11 5AD