

visit made. met tom dimmock who is responsible for the petrol station.petroleum license valid until 31.05.12.Saw Gilbarco certificate for stage 1b 3rd year inspection. Valid until 21.04.12.

Checked all connection points and saw signs stating max number of tanks (2) and connection procedure sign. all padlocked. Checked seal on the petrol fuel tanks and noted that one was damaged. Asked Mr Dimmock to arrange for replacement. to send letter out.

Gilbarco attend to calls/incidents. If non-emergency, standard call out response time is 8hrs. Checked paperwork regarding petrol station weekly checks. These were comprehensive and included checking VR system, kinks etc.

All deliveries are DCD.

Asked for vr2 paperworkbut none on site. agreed to ask for them.

training provided to all staff including in case of emergency.