

visit made. met with site manager. noted that permit incorrect as it authorises Morrisons Supermarkets!! it is unsigned and undated/Permit also refers to five storage tanks but doesn't mention number of petrol tanks. Permit is therefore in need of a revision.

Number of petrol tanks: 2

Petrol station operates under VR1 as throughput lower than threshold.

Petroman Env Services visit every year.

PVVV, cap and lock, supply hose were replaced on 23.09.11 as part of yearly visit.

The previous certificate ran out on the 24.04.10 and petroman have not issued a new certificate yet.

The VR signs need to be replaced and this was pointed out to the manager. The seals were checked and were ok.