

Our ref: WK/201207016  
Please ask for: Louise Burns  
Direct Dial: 01473 433039  
Email: Louise.burns@ipswich.gov.uk



Petrogas Applegreen Heath  
Shell Service Station  
23-27 Woodbridge Road East  
Ipswich  
Suffolk  
IP4 5QN

Grafton House  
15-17 Russell Road  
Ipswich Suffolk  
IP1 2DE

[www.ipswich.gov.uk](http://www.ipswich.gov.uk)

26th November 2012

Dear Sir

**Pollution Prevention and Control Act 1999**  
**The Environmental Permitting (England and Wales) Regulations 2010**  
**Permit Inspection - Shell Service Station, 23 Woodbridge Road East, Ipswich, Suffolk, IP4 5QN.**

An inspection of the above installation was carried out on 26<sup>th</sup> November 2012. The operation of your permitted activity was generally found to be satisfactory and complies with the conditions of your Permit Ref. No. PS5/DJR/01/12.

I draw your attention to condition 13 of the permit which requires that you have a legible durable notice on the vapour return connection point instruction the user to 'connect vapour return line before off-loading'. This notice was broken and in need of repair.

Under the risk based method for permitted activities, your installation has been assessed as LOW risk. This will affect the frequency of inspections and the annual subsistence charge.

If you have any queries, please do not hesitate to contact me on 433039.

Yours sincerely

Louise Burns  
Environmental Health Officer  
Environmental Health