

# STACK EMISSIONS MONITORING REPORT



Unit D  
Bankside Trade Park  
Cirencester  
GL7 1YT  
Tel: 01285 700 593

## Your contact at ESG

Mike Davies  
Business Manager - South  
Tel: 07976 297 465  
Email: mike.davies@esg.co.uk

## Operator & Address:

Bolton Aerospace Limited  
PO Box 22  
Hadleigh Road  
Ipswich  
Suffolk  
IP2 0EG

## Permit:

EPR Permit: EP54/1/LB

## Release Point:

A1 - Main Stack

## Sampling Date(s):

14th & 15th September 2016

<b>ESG Job Number:</b>	LSO 160910
<b>Report Date:</b>	25th October 2016
<b>Version:</b>	1
<b>Report By:</b>	Owen May
<b>MCERTS Number:</b>	MM 10 1072
<b>MCERTS Level:</b>	MCERTS Level 2 - Team Leader
<b>Technical Endorsements:</b>	1, 2, 3 & 4
<b>Report Approved By:</b>	Mike Davies
<b>MCERTS Number:</b>	MM 02 087
<b>Business Title:</b>	MCERTS Level 2 - Business Manager
<b>Technical Endorsements:</b>	1, 2, 3 & 4
<b>Signature:</b>	



1015

## CONTENTS

### EXECUTIVE SUMMARY

#### Stack Emissions Monitoring Objectives

- Plant
- Operator
- Stack Emissions Monitoring Test House

#### Emissions Summary

#### Monitoring Times

#### Process Details

#### Monitoring Methods

#### Analytical Methods

- Sampling Methods with Subsequent Analysis
- On-Site Testing

#### Sampling Location

- Sampling Plane Validation Criteria
- Duct Characteristics
- Sampling Lines & Sample Points
- Sampling Platform
- Sampling Location / Platform Improvement Recommendations

#### Sampling and Analytical Method Deviations

### APPENDICES

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

APPENDIX 3 - Measurement Uncertainty Budget Calculations

## EXECUTIVE SUMMARY

### MONITORING OBJECTIVES

Bolton Aerospace Limited operates a non-ferrous alloy production process at Ipswich which is subject to EPR Permit EP54/1/LB, under the Environmental Permitting Regulations 2010.

ESG were commissioned by Bolton Aerospace Limited to carry out stack emissions monitoring to determine the release of prescribed pollutants from the following Plant under normal operating conditions.

The results of these tests shall be used to demonstrate compliance with a set of emission limit values for prescribed pollutants as specified in the Plant's EPR Permit, EP54/1/LB.

#### Plant

A1 - Main Stack

#### Operator

Bolton Aerospace Limited  
PO Box 22  
Hadleigh Road  
Ipswich  
Suffolk  
IP2 0EG

EPR Permit: EP54/1/LB

#### Stack Emissions Monitoring Test House

ESG - Cirencester Laboratory  
Unit D  
Bankside Trade Park  
Cirencester  
GL7 1YT  
UKAS and MCERTS Accreditation Number: 1015

Opinions and interpretations expressed herein are outside the scope of UKAS accreditation.  
MCERTS accredited results will only be claimed where both the sampling and analytical stages are UKAS accredited.  
This test report shall not be reproduced, except in full, without written approval of ESG.

## EXECUTIVE SUMMARY

EMISSIONS SUMMARY					
Parameter	Units	Result	Calculated Uncertainty +/-	Limit	MCERTS accredited result
Total Particulate Matter	mg/m <sup>3</sup>	11.1	0.69	20	✓
Particulate Emission Rate	g/hr	950	58.9	-	
<b>Dioxins &amp; Furans - UPPER Limits</b>					
Dioxins & Furans (NATO I-TEQ)	ng/m <sup>3</sup>	0.0139	0.0028	1.0	✓
Dioxins & Furans (NATO I-TEQ) Emission Rate	µg/hr	1.2381	0.2501	-	
Dioxins & Furans (WHO TEQ Humans / Mammals)	ng/m <sup>3</sup>	0.0131	0.0026	-	✓
Dioxins & Furans (WHO TEQ H / M) Emission Rate	µg/hr	1.1689	0.2361	-	
Dioxins & Furans (WHO TEQ Fish)	ng/m <sup>3</sup>	0.0155	0.0031	-	✓
Dioxins & Furans (WHO TEQ Fish) Emission Rate	µg/hr	1.3791	0.2786	-	
Dioxins & Furans (WHO TEQ Birds)	ng/m <sup>3</sup>	0.0265	0.0054	-	✓
Dioxins & Furans (WHO TEQ Birds) Emission Rate	µg/hr	2.3659	0.4779	-	
<b>Dioxins &amp; Furans - LOWER Limits</b>					
Dioxins & Furans (NATO I-TEQ)	ng/m <sup>3</sup>	0.0139	0.0028	-	✓
Dioxins & Furans (NATO I-TEQ) Emission Rate	µg/hr	1.2381	0.2501	-	
Dioxins & Furans (WHO TEQ Humans / Mammals)	ng/m <sup>3</sup>	0.0131	0.0026	-	✓
Dioxins & Furans (WHO TEQ H / M) Emission Rate	µg/hr	1.1689	0.2361	-	
Dioxins & Furans (WHO TEQ Fish)	ng/m <sup>3</sup>	0.0155	0.0031	-	✓
Dioxins & Furans (WHO TEQ Fish) Emission Rate	µg/hr	1.3791	0.2786	-	
Dioxins & Furans (WHO TEQ Birds)	ng/m <sup>3</sup>	0.0265	0.0054	-	✓
Dioxins & Furans (WHO TEQ Birds) Emission Rate	µg/hr	2.3659	0.4779	-	
<b>Dioxin-like PCBs - UPPER Limits</b>					
Dioxin-like PCBs (WHO TEQ Humans / Mammals)	ng/m <sup>3</sup>	0.0031	0.0004	-	✓
Dioxin-like PCBs (WHO TEQ H / M) Emission Rate	µg/hr	0.2736	0.0331	-	
Dioxin-like PCBs (WHO TEQ Fish)	ng/m <sup>3</sup>	0.0002	0.0000	-	✓
Dioxin-like PCBs (WHO TEQ Fish) Emission Rate	µg/hr	0.0176	0.0021	-	
Dioxin-like PCBs (WHO TEQ Birds)	ng/m <sup>3</sup>	0.0153	0.0019	-	✓
Dioxin-like PCBs (WHO TEQ Birds) Emission Rate	µg/hr	1.3650	0.1652	-	
<b>Dioxin-like PCBs - LOWER Limits</b>					
Dioxin-like PCBs (WHO TEQ Humans / Mammals)	ng/m <sup>3</sup>	0.0031	0.0004	-	✓
Dioxin-like PCBs (WHO TEQ H / M) Emission Rate	µg/hr	0.2736	0.0331	-	
Dioxin-like PCBs (WHO TEQ Fish)	ng/m <sup>3</sup>	0.0002	0.0000	-	✓
Dioxin-like PCBs (WHO TEQ Fish) Emission Rate	µg/hr	0.0176	0.0021	-	
Dioxin-like PCBs (WHO TEQ Birds)	ng/m <sup>3</sup>	0.0153	0.0019	-	✓
Dioxin-like PCBs (WHO TEQ Birds) Emission Rate	µg/hr	1.3650	0.1652	-	
Cadmium & Thallium	mg/m <sup>3</sup>	0.0009	0.0002	1	✓
Cadmium & Thallium Emission Rate	g/hr	0.0794	0.0181	-	
Heavy Metals	mg/m <sup>3</sup>	12.82	2.922	32	✓
Heavy Metals Emission Rate	g/hr	1178	269	-	
Lead	mg/m <sup>3</sup>	0.52941	0.1207	2	✓
Lead Emissions Rate	g/hr	48.662	11.0949	-	
Tin	mg/m <sup>3</sup>	0.00041	0.00009	5	✓
Tin Emission Rate	g/hr	0.0379	0.0086	-	
Copper	mg/m <sup>3</sup>	0.29755	0.0678	20	✓
Copper Emission Rate	g/hr	27.35	6.2358	-	
Nickel	mg/m <sup>3</sup>	0.0169	0.0039	5	✓
Nickel Emission Rate	g/hr	1.5532	0.3541	-	
Cobalt, Chromium and Cadmium	mg/m <sup>3</sup>	0.01134	0.0026	1	✓
Cobalt, Chromium and Cadmium Emission Rate	g/hr	1.043	0.2378	-	
Hydrogen Fluoride	mg/m <sup>3</sup>	<b>0.02</b>	0.001	5	✓
Hydrogen Fluoride Emission Rate	g/hr	<b>1.57</b>	0.142	-	
Moisture	%	1.03	0.0	-	✓
Stack Gas Temperature	°C	30	-	-	
Stack Gas Velocity	m/s	12.4	0.31	-	
Gas Volumetric Flow Rate (Actual)	m <sup>3</sup> /hr	107263	5578	-	✓
Gas Volumetric Flow Rate (STP, Wet)	m <sup>3</sup> /hr	96972	5043	-	
Gas Volumetric Flow Rate (STP, Dry)	m <sup>3</sup> /hr	95969	4990	-	
Gas Volumetric Flow Rate at Reference Conditions	m <sup>3</sup> /hr	96972	5043	-	

ND = None Detected,

Results at or below the limit of detection are highlighted by bold italic text.

The above volumetric flow rate is calculated using data from the preliminary survey. Mass emissions for non isokinetic tests are calculated using these values. For all isokinetic testing the mass emission is calculated using test specific flow data and not the above values.

Reference conditions are 273K, 101.3kPa without correction for water vapour

## EXECUTIVE SUMMARY

MONITORING TIMES			
Parameter	Sampling Date(s)	Sampling Times	Sampling Duration
Total Particulate Matter Run 1	15 September 2016	09:40 - 11:11	90 minutes
Dioxins, Furans & Dioxin-like PCBs Run 1	14 September 2016	07:44 - 13:50	360 minutes
Cadmium & Thallium Run 1	15 September 2016	08:00 - 09:34	90 minutes
Heavy Metals Run 1	15 September 2016	08:00 - 09:34	90 minutes
Hydrogen Fluoride Run 1	14 September 2016	07:50 - 13:50	360 minutes
Preliminary Stack Traverse	14 September 2016	07:30	-

## EXECUTIVE SUMMARY

### PROCESS DETAILS

Parameter	Process Details
Description of process	Non-ferrous alloy production
Continuous or batch	Batch
Product Details	Various metal alloy components
Part of batch to be monitored (if applicable)	Any 6 hour part
Normal load, throughput or continuous rating	Approx 700kg / hour
Fuel used during monitoring	N/A
Abatement	None
Plume Appearance	None Visible

## EXECUTIVE SUMMARY

### Monitoring Methods

The selection of standard reference / alternative methods employed by ESG is determined, wherever possible by the hierarchy of method selection outlined in Environment Agency Technical Guidance Note (Monitoring) M2. i.e. CEN, ISO, BS, US EPA etc.

MONITORING METHODS						
Species	Method Standard Reference Method / Alternative Method	ESG Technical Procedure	UKAS Lab Number	MCERTS Accredited Method	Limit of Detection (LOD)	Calculated MU +/- %
TPM	SRM - BS EN 13284-1	AE 104	1015	Yes	0.3 mg/m <sup>3</sup>	6.2 %
PCDD/PCDF	SRM - BS EN 1948-1	AE 109	1015	Yes	0.001 ng/m <sup>3</sup>	20.2 %
PCBs	SRM - BS EN 1948-1	AE 109	1015	Yes	0 ng/m <sup>3</sup>	12.1 %
Cd & Tl	SRM - BS EN 14385	AE 108	1015	Yes	0.00065 mg/m <sup>3</sup>	22.8 %
Heavy Metals	SRM - BS EN 14385	AE 108	1015	Yes	0.005 mg/m <sup>3</sup>	22.8 %
Hydrogen Fluoride	SRM - BS ISO 15713	AE 113	1015	Yes	0 mg/m <sup>3</sup>	9 %
H <sub>2</sub> O	SRM - BS EN 14790	AE 105	1015	Yes	0%	2.9%
Velocity	SRM - BS EN ISO 16911-1	AE 154	1015	Yes	5 Pa	2.5 %

BS EN 14790 has been validated over a range of 4 - 40%. It is however the preferred method of the Environment Agency for concentrations below 4%

## EXECUTIVE SUMMARY

### Analytical Methods

The following tables list the analytical methods employed together with the custody and archiving details:

SAMPLING METHODS WITH SUBSEQUENT ANALYSIS							
Species	Analytical Technique	Analytical Procedure	UKAS Lab Number	UKAS Accredited Lab Analysis	Analysis Lab (ESG or Subcontract)	Sample Archive Location	Archive Period
TPM	Gravimetric	AE 106	1015	Yes	ESG - Cirencester	ESG - Cirencester	3 months
PCDD/PCDF	Gas Chromatography - High Resolution Mass Spectrometry	ANU/SOP/3007	1549	Yes	ESG Bretby	ESG Bretby	3 months
PCBs	Gas Chromatography - High Resolution Mass Spectrometry	ANU/SOP/3004	1549	Yes	ESG Bretby	ESG Bretby	3 months
Cd & Tl	Inductively coupled Plasma - Mass Spectrometry	ANU/SOP/117, 101,102	1015	Yes	ESG Bretby	ESG Bretby	3 months
Heavy Metals	Inductively coupled Plasma - Mass Spectrometry	ANU/SOP/117, 101,102	1015	Yes	ESG Bretby	ESG Bretby	3 months
Hydrogen Fluoride	Ion Chromatography	ASC/SOP/110/10	1015	Yes	ESG Bretby	ESG Bretby	3 months

ON-SITE TESTING							
Species	Analytical Technique	Analytical Procedure	UKAS Lab Number	MCERTS Accredited Analysis	Laboratory	Data Archive Location	Archive Period
H <sub>2</sub> O	Gravimetric	AE 105	1015	Yes	ESG - Cirencester	-	-



## EXECUTIVE SUMMARY

SAMPLING LOCATION					
Sampling Plane Validation Criteria	Value	Units	Requirement	Compliant	Method
Lowest Differential Pressure	124	Pa	>= 5 Pa	Yes	BS EN 15259
Lowest Gas Velocity	11.95	m/s	-	-	-
Highest Gas Velocity	12.74	m/s	-	-	-
Ratio of Gas Velocities	1.07	:1	< 3 : 1	Yes	BS EN 15259
Mean Velocity	12.39	m/s	-	-	-
Maximum angle of flow with regard to duct axis	<15	°	< 15°	Yes	BS EN 15259
No local negative flow	Yes	-	-	Yes	BS EN 15259

DUCT CHARACTERISTICS		
	Value	Units
Shape	Circular	-
Depth	1.75	m
Width	-	m
Area	2.41	m <sup>2</sup>
Port Depth	90	mm

SAMPLING LINES & POINTS		
	Isokinetic	Non-Iso & Gases
Sample port size	4 " BSP	-
Number of lines used	2	-
Number of points / line	3	-
Duct orientation	Vertical	-
Filtration for TPM	QF	-

SAMPLING PLATFORM	
General Platform Information	
Permanent / Temporary Platform / Ground level / Floor Level / Roof	Permanent
Inside / Outside	Outside

M1 Platform requirements	
Is there a sufficient working area so work can be performed in a compliant manner	No
Platform has 2 levels of handrails (approximately 0.5 m & 1.0 m high)	Yes
Platform has vertical base boards (approximately 0.25 m high)	Yes
Platform has removable chains / self closing gates at the top of ladders	Yes
Handrail / obstructions do not hamper insertion of sampling equipment	No
Depth of Platform = >Stack depth / diameter + wall and port thickness + 1.5m	No

### Sampling Platform Improvement Recommendations (if applicable)

The sampling location should meet all the requirements as specified in EA Guidance Note M1.

## EXECUTIVE SUMMARY

### Sampling & Analytical Method Deviations

#### Sampling points

Due to the limited size of the platform, it was not possible to test the sampling points towards the far-wall of both sampling lines.

## APPENDICES

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

APPENDIX 3 - Measurement Uncertainty Budget Calculations

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

MONITORING SCHEDULE					
Species	Method Standard Reference Method / Alternative Method	ESG Technical Procedure	UKAS Lab Number	MCERTS Accredited Method	Number of Samples
TPM	SRM - BS EN 13284-1	AE 104	1015	Yes	1
PCDD/PCDF	SRM - BS EN 1948-1	AE 109	1015	Yes	1
PCBs	SRM - BS EN 1948-1	AE 109	1015	Yes	1
Cd & Tl	SRM - BS EN 14385	AE 108	1015	Yes	1
Heavy Metals	SRM - BS EN 14385	AE 108	1015	Yes	1
Hydrogen Fluoride	SRM - BS ISO 15713	AE 113	1015	Yes	1
H <sub>2</sub> O	SRM - BS EN 14790	AE 105	1015	Yes	1
Velocity	SRM - BS EN ISO 16911-1	AE 154	1015	Yes	1

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

CALIBRATEABLE EQUIPMENT CHECKLIST					
Extractive Sampling		Instrumental Analyser/s		Miscellaneous	
Equipment	Equipment I.D.	Equipment	Equipment I.D.	Equipment	Equipment I.D.
Control Box DGM	P1268	Horiba PG-250 Analyser	-	Laboratory Balance	P66
Box Thermocouples	P1268	FT-IR	-	Tape Measure	P2024
Meter In Thermocouple	P1268	FT-IR Oven Box	-	Stopwatch	P2614
Meter Out Thermocouple	P1268	Bernath 3006 FID	-	Protractor	-
Control Box Timer	-	Signal 3030 FID	-	Barometer	P1916
Oven Box	P1375	Servomex	-	Digital Micromanometer	P1915
Probe	P2628	JCT Heated Head Filter	-	Digital Temperature Meter	P1745
Probe Thermocouple	P2628	Thermo FID	-	Stack Thermocouple	-
Probe	-	Stackmaster	-	Mass Flow Controller	-
Probe Thermocouple	-	FTIR Heater Box for Heated Line	-	MFC Display module	-
S-Pitot	P2078	Anemometer	-	1m Heated Line (1)	-
L-Pitot	-	Ecophysics NOx Analyser	-	1m Heated Line (2)	-
Site Balance	P1952	Chiller (JCT/MAK 10)	-	1m Heated Line (3)	-
Last Impinger Arm	P2171	Heated Line Controller (1)	-	5m Heated Line (1)	-
Dioxins Cond. Thermocouple	P1980	Heated Line Controller (2)	P1930	10m Heated Line (1)	-
Callipers	-	Site temperature Logger	-	10m Heated Line (2)	-
Small DGM	-	-	-	15m Heated Line (1)	-
Wet Gas Meter	P497	-	-	20m Heated Line (1)	P2403
Inclinometer (Swirl Device)	P2096	-	-	20m Heated Line (2)	-

NOTE: If the equipment I.D is represented by a dash (-), then this piece of equipment has not been used for this test.

CALIBRATION GASES					
Gas (traceable to ISO 17025)	Cylinder I.D Number	Supplier	ppm	%	Analytical Tolerance +/- %
-	-	-	-	-	-

**STACK EMISSIONS MONITORING TEAM**

MONITORING TEAM								
Personnel	MCERTS Number	MCERTS		TE / H&S Qualifications and Expiry Date				
		Level	Expiry	TE1	TE2	TE3	TE4	H&S
Owen May	MM 10 1072	MCERTS Level 2	Feb-18	Sep-21	Jun-21	Mar-17	Mar-22	Jun-20
Jamie Whiteman	MM 16 1364	MCERTS Level 1	Jan-21	-	-	-	-	Jan-19

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

TOTAL PARTICULATE MATTER SUMMARY					
Parameter	Sampling Times	Concentration mg/m <sup>3</sup>	Uncertainty mg/m <sup>3</sup>	Limit mg/m <sup>3</sup>	Emission Rate g/hr
Run 1	09:40 - 11:11 15 September 2016	11.1	0.68	20	950
Blank	-	0.30	-	-	-

Reference conditions are 273K, 101.3kPa without correction for water vapour

Acetone Blank Value mg/l	Acceptable Value mg/l
2.0	10

**FILTER INFORMATION**

SAMPLES								
Test	Filter & Probe Rinse Number	Filter Start Weight g	Filter End Weight g	Mass Gained on Filter g	Probe Rinse Start Weight g	Probe Rinse End Weight g	Mass Gained on Probe g	Combined Total Mass Gained g
Run 1	038690	0.15430	0.17090	0.01660	71.71890	71.72070	0.00180	0.01840

If total mass gained is less than the LOD then the LOD is reported

BLANKS								
Test	Filter & Probe Number	Filter Start Weight g	Filter End Weight g	Mass Gained Filter g	Probe Start Weight g	Probe End Weight g	Mass Gained Probe g	Combined Total Mass Gained g
Run 1	038689	0.15220	0.15230	0.00010	68.52890	68.52890	0.00000	0.00050

If total mass gained is less than the LOD then the LOD is reported

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS - RUN 1			TPM	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	759.01	CO <sub>2</sub>	% 0.03
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	-3.98	O <sub>2</sub>	% 20.90
$P_s = P_b + (P_{static})$	mm Hg	758.72	Total	% 20.93
$13.6$			N <sub>2</sub> (100 - Total)	% 79.07
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			$M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2)$	
Moisture trap weight increase, Vlc	g	H <sub>2</sub> O by Non Iso	<b>Molecular weight of wet gas, M<sub>s</sub></b>	
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	$M_s = M_d(1 - B_{wo}) + 18(B_{wo})$	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			<b>Actual flow of stack gas, Q<sub>a</sub></b>	
Volume of gas sample through gas meter, V <sub>m</sub>		1.821	Area of stack, A <sub>s</sub>	m <sup>2</sup> 2.41
Gas meter correction factor, Y <sub>d</sub>		1.0135	$Q_a = (60)(A_s)(V_s)$	m <sup>3</sup> /min 1599.0
Mean dry gas meter temperature, T <sub>m</sub>		34.458	<b>Total flow of stack gas, Q</b>	
Mean pressure drop across orifice, DH mmH <sub>2</sub> O		45.107	Conversion factor (K/mm.Hg)	
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (DH/13.6))(Y_d)}{T_m + 273}$		1.644	Q <sub>std</sub> = $\frac{(Q_a)P_s(0.3592)(1 - B_{wo})}{(T_s) + 273}$ Dry 1414.0	
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			$Q_{std02} = \frac{(Q_a)P_s(0.3592)(1 - B_{wo})(O_2REF)}{(T_s) + 273}$ @O <sub>2</sub> ref No O <sub>2</sub> Ref	
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	1.6609	$Q_{stw} = \frac{(Q_a)P_s(0.3592)}{(T_s) + 273}$ Wet 1428.78	
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O2</sub></b>			<b>Percent isokinetic, %I</b>	
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	Nozzle diameter, D <sub>n</sub>	
% oxygen measured in gas stream, act%O <sub>2</sub>		20.9	mm 6.22	
% oxygen reference condition		21	Nozzle area, A <sub>n</sub>	
O <sub>2</sub> Reference O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>		No O <sub>2</sub> Ref	mm <sup>2</sup> 30.39	
Factor $\frac{21.0 - ref\%O_2}{21.0 - act\%O_2}$		No O <sub>2</sub> Ref	Total sampling time, q	
$V_{mstd@X\%oxygen} = (V_{mstd})(O_2 Ref)$	m <sup>3</sup>	No O <sub>2</sub> Ref	min 90	
<b>Moisture content, B<sub>wo</sub></b>			$\%I = \frac{(4.6398E6)(T_s + 273)(V_{mstd})}{(P_s)(V_s)(A_n)(q)(1 - B_{wo})}$ % 102.2	
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	0.0103	Acceptable isokinetic range 95% to 115%	
		1.03	Yes	
<b>Moisture by FTIR</b>			<b>Particulate Concentration, C</b>	
	%	-	Mass collected on filter, M <sub>f</sub>	
<b>Velocity of stack gas, V<sub>s</sub></b>			g 0.01660	
Pitot tube velocity constant, K <sub>p</sub>		34.97	Mass collected in probe, M <sub>p</sub>	
Velocity pressure coefficient, C <sub>p</sub>		0.82	g 0.00180	
Mean of velocity heads, DP <sub>avg</sub> mm H <sub>2</sub> O		10.67	Total mass collected, M <sub>n</sub>	
Mean square root of velocity heads, ÖDP		3.27	g 0.01840	
Mean stack gas temperature, T <sub>s</sub> °C		32	$C_{wet} = \frac{M_n}{V_{mstw}}$ mg/m <sup>3</sup> 11.078	
$V_s = \frac{(K_p)(C_p)(\ddot{O}DP)(\ddot{O}(T_s + 273))}{(M_s)(P_s)}$	m/s	11.08	$C_{dry} = \frac{M_n}{V_{mstd}}$ mg/m <sup>3</sup> 11.194	
			$C_{dry@X\%O_2} = \frac{M_n}{V_{mstd@X\%oxygen}}$ mg/m <sup>3</sup> No O <sub>2</sub> Ref	
			<b>Particulate Emission Rates, E</b>	
			$E = [(C_{wet})(Q_{stw})(60)] / 1000$	
			949.72	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**TOTAL PARTICULATE MATTER QUALITY ASSURANCE CHECKLIST**

LEAK RATE						
Run	Mean Sampling Rate litre/min	Pre-sampling Leak Rate litre/min	Post-sampling Leak Rate litre/min	Maximum Vacuum mm Hg	Acceptable Leak Rate litre/min	Leak Tests Acceptable?
Run 1	20.51	0.18	0.24	-406.4	0.41	Yes

ISOKINETICITY		
Run	Isokinetic Variation %	Acceptable Isokineticity
Run 1	102.24	Yes

Acceptable isokinetic range 95% to 115%

WEIGHING BALANCE UNCERTAINTY			
Run	Result mg/m <sup>3</sup>	5% ELV mg/m <sup>3</sup>	LOD < 5% ELV
Run 1	0.30	1	Yes

The above is based on both the Filter and rinse uncertainty

BLANK VALUE				
Run	Overall Blank Value mg/m <sup>3</sup>	Daily Emission Limit Value mg/m <sup>3</sup>	Acceptable Blank Value mg/m <sup>3</sup>	Overall Blank Acceptable mg/m <sup>3</sup>
Blank 1	0.30	20	2.0	Yes

FILTERS					
Run	Filter Material	Filter Size mm	Max Filtration Temperature °C	Pre-use Filter Conditioning Temperature °C	Post-use Filter Conditioning Temperature °C
Run 1	QF	47	32	180	160

GF = Glass Fibre  
QF = Quartz Fibre



APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**DIOXINS & FURANS SUMMARY - UPPER LIMIT**

NATO I-TEQ					
Test	Sampling Times	Concentration ng/m <sup>3</sup>	LOD ng/m <sup>3</sup>	Limit ng/m <sup>3</sup>	Emission Rate µg/hr
Run 1	07:44 - 13:50 14 September 2016	0.01389	0.00137	1	1.24
Field Blanks Run 1	-	0.00137	-	-	-

WHO TEQ (Humans / Mammals)					
Test	Sampling Times	Concentration ng/m <sup>3</sup>	LOD ng/m <sup>3</sup>	Limit ng/m <sup>3</sup>	Emission Rate µg/hr
Run 1	07:44 - 13:50 14 September 2016	0.01311	0.00173	-	1.17
Field Blanks Run 1	-	0.00157	-	-	-

WHO TEQ (Fish)					
Test	Sampling Times	Concentration ng/m <sup>3</sup>	LOD ng/m <sup>3</sup>	Limit ng/m <sup>3</sup>	Emission Rate µg/hr
Run 1	07:44 - 13:50 14 September 2016	0.01547	0.00201	-	1.38
Field Blanks Run 1	-	0.00173	-	-	-

WHO TEQ (Birds)					
Test	Sampling Times	Concentration ng/m <sup>3</sup>	LOD ng/m <sup>3</sup>	Limit ng/m <sup>3</sup>	Emission Rate µg/hr
Run 1	07:44 - 13:50 14 September 2016	0.02654	0.00201	-	2.37
Field Blanks Run 1	-	0.00201	-	-	-

Reference conditions are 273K, 101.3kPa without correction for water vapour

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**DIOXINS & FURANS SUMMARY - LOWER LIMIT**

NATO I-TEQ					
Test	Sampling Times	Concentration ng/m <sup>3</sup>	LOD ng/m <sup>3</sup>	Limit ng/m <sup>3</sup>	Emission Rate µg/hr
Run 1	07:44 - 13:50 14 September 2016	0.01389	-	1	1.24
Field Blanks Run 1	-	0.00000	-	-	-

WHO TEQ (Humans / Mammals)					
Test	Sampling Times	Concentration ng/m <sup>3</sup>	LOD ng/m <sup>3</sup>	Limit ng/m <sup>3</sup>	Emission Rate µg/hr
Run 1	07:44 - 13:50 14 September 2016	0.01311	-	-	1.17
Field Blanks Run 1	-	0.00000	-	-	-

WHO TEQ (Fish)					
Test	Sampling Times	Concentration ng/m <sup>3</sup>	LOD ng/m <sup>3</sup>	Limit ng/m <sup>3</sup>	Emission Rate µg/hr
Run 1	07:44 - 13:50 14 September 2016	0.01547	-	-	1.38
Field Blanks Run 1	-	0.00000	-	-	-

WHO TEQ (Birds)					
Test	Sampling Times	Concentration ng/m <sup>3</sup>	LOD ng/m <sup>3</sup>	Limit ng/m <sup>3</sup>	Emission Rate µg/hr
Run 1	07:44 - 13:50 14 September 2016	0.02654	-	-	2.37
Field Blanks Run 1	-	0.00000	-	-	-

Reference conditions are 273K, 101.3kPa without correction for water vapour

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**DIOXINS & FURANS ANALYSIS SUMMARY - RUN 1**

NATO I-TEQ & WHO TEQ (Humans / Mammals)					
Congener	Result ng	NATO I-TEQ ng	WHO TEQ Humans / Mammals ng	Extraction Recovery	
				Actual %	Permitted %
<b>Dioxins</b>					
2378 Tetra CDD	0.0033	0.0033	0.0033	67	50 - 130
12378 Penta CDD	0.025	0.0125	0.025	58	50 - 130
123478 Hexa CDD	0.0073	0.00073	0.00073	0	50 - 130
123678 Hexa CDD	0.0088	0.00088	0.00088	81	50 - 130
123789 Hexa CDD	0.0087	0.00087	0.00087		
1234678 Hepta CDD	0.073	0.00073	0.00073	63	50 - 130
OCDD Octa CDD	0.08	0.00008	0.000024	48	20 - 150
<b>Total -Dioxins</b>	<b>0.2061</b>	<b>0.01909</b>	<b>0.031534</b>		
<b>Furans</b>					
2378 Tetra CDF	0.042	0.0042	0.0042	65	50 - 130
12378 Penta CDF	0.049	0.00245	0.00147	56	>=50
23478 Penta CDF	0.084	0.042	0.0252	0	50 - 130
123478 Hexa CDF	0.07	0.007	0.007	0	50 - 130
123678 Hexa CDF	0.078	0.0078	0.0078	83	50 - 130
234678 Hexa CDF	0.085	0.0085	0.0085	0	50 - 130
123789 Hexa CDF	0.027	0.0027	0.0027	65	>=50
1234678 Hepta CDF	0.22	0.0022	0.0022	68	20 - 150
1234789 Hepta CDF	0.018	0.00018	0.00018	0	>=50
OCDF Octa CDF	0.057	0.000057	0.0000171	0	20 - 150
<b>Total -Furans</b>	<b>0.73</b>	<b>0.077087</b>	<b>0.0592671</b>		
<b>Mean Recoveries (%)</b>				<b>65</b>	
<b>Total Isomers  </b>	<b>0.9361</b>	<b>0.09618</b>	<b>0.09080</b>		
<b>Total ITEQ (&lt;LOD = 0)</b>		<b>0.09618</b>	<b>0.09080</b>		

NOTE: The Total Isomers result includes all isomers below the limit of detection. This gives a "worst case" Dioxins & Furans result.

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**DIOXINS & FURANS ANALYSIS SUMMARY - RUN 1**

WHO TEQ (Fish) & WHO TEQ (Birds)					
Congener	Result	WHO TEQ Fish	WHO TEQ Birds	Extraction Recovery	
				Actual	Permitted
	ng	ng	ng	%	%
<b>Dioxins</b>					
2378 Tetra CDD	0.0033	0.0033	0.0033	67	50 - 130
12378 Penta CDD	0.025	0.025	0.025	58	50 - 130
123478 Hexa CDD	0.0073	0.00365	0.000365	0	50 - 130
123678 Hexa CDD	0.0088	0.000088	0.000088	81	50 - 130
123789 Hexa CDD	0.0087	0.000087	0.000087		
1234678 Hepta CDD	0.073	0.000073	0.000073	63	50 - 130
OCDD Octa CDD	0.08	-	-	48	20 - 150
<b>Total -Dioxins</b>	<b>0.2061</b>	<b>0.032198</b>	<b>0.028913</b>		
<b>Furans</b>					
2378 Tetra CDF	0.042	0.0021	0.042	65	50 - 130
12378 Penta CDF	0.049	0.00245	0.00049	56	>=50
23478 Penta CDF	0.084	0.042	0.084	0	50 - 130
123478 Hexa CDF	0.07	0.007	0.007	0	50 - 130
123678 Hexa CDF	0.078	0.0078	0.0078	83	50 - 130
234678 Hexa CDF	0.085	0.0085	0.0085	0	50 - 130
123789 Hexa CDF	0.027	0.0027	0.0027	65	>=50
1234678 Hepta CDF	0.22	0.0022	0.0022	68	20 - 150
1234789 Hepta CDF	0.018	0.00018	0.00018	0	>=50
OCDF Octa CDF	0.057	0.0000057	0.0000057	0	20 - 150
<b>Total -Furans</b>	<b>0.73</b>	<b>0.0749357</b>	<b>0.1548757</b>		
<b>Mean Recoveries (%)</b>				<b>65</b>	
<b>Total Isomers</b>	<b>0.9361</b>	<b>0.1071337</b>	<b>0.1837887</b>		
<b>Total ITEQ (&lt;LOD = 0)</b>		<b>0.1071337</b>	<b>0.1837887</b>		

NOTE: The Total Isomers result includes all isomers below the limit of detection. This gives a "worst case" Dioxins & Furans result.

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**DIOXINS & FURANS ANALYSIS SUMMARY - FIELD BLANK RUN 1**

NATO I-TEQ & WHO TEQ (Humans / Mammals)					
Congener	Result	NATO I-TEQ	WHO TEQ Humans / Mammals	Extraction Recovery	
				Actual	Permitted
	ng	ng	ng	%	%
<b>Dioxins</b>					
2378 Tetra CDD	< 0.003	0.003	0.003	78	50 - 130
12378 Penta CDD	< 0.004	0.002	0.004	66	50 - 130
123478 Hexa CDD	< 0.003	0.0003	0.0003	0	50 - 130
123678 Hexa CDD	< 0.003	0.0003	0.0003	88	50 - 130
123789 Hexa CDD	< 0.003	0.0003	0.0003		
1234678 Hepta CDD	< 0.009	0.00009	0.00009	64	50 - 130
OCDD Octa CDD	< 0.02	0.00002	0.000006	44	20 - 150
<b>Total -Dioxins</b>	<b>0.045</b>	<b>0.00601</b>	<b>0.007996</b>		
<b>Furans</b>					
2378 Tetra CDF	< 0.002	0.0002	0.0002	73	50 - 130
12378 Penta CDF	< 0.002	0.0001	0.00006	62	>=50
23478 Penta CDF	< 0.003	0.0015	0.0009	0	50 - 130
123478 Hexa CDF	< 0.004	0.0004	0.0004	0	50 - 130
123678 Hexa CDF	< 0.004	0.0004	0.0004	88	50 - 130
234678 Hexa CDF	< 0.004	0.0004	0.0004	0	50 - 130
123789 Hexa CDF	< 0.004	0.0004	0.0004	69	>=50
1234678 Hepta CDF	< 0.004	0.00004	0.00004	69	20 - 150
1234789 Hepta CDF	< 0.005	0.00005	0.00005	0	>=50
OCDF Octa CDF	< 0.01	0.00001	0.000003	0	20 - 150
<b>Total -Furans</b>	<b>0.042</b>	<b>0.0035</b>	<b>0.002853</b>		
<b>Mean Recoveries (%)</b>				<b>70</b>	
<b>Total Isomers</b>	<b>0.087</b>	<b>0.00951</b>	<b>0.010849</b>		
<b>Total ITEQ (&lt;LOD = 0)</b>		<b>0</b>	<b>0</b>		

NOTE: The Total Isomers result includes all isomers below the limit of detection. This gives a "worst case" Dioxins & Furans result.

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**DIOXINS & FURANS ANALYSIS SUMMARY - FIELD BLANK RUN 1**

WHO TEQ (Fish) & WHO TEQ (Birds)					
Congener	Result	WHO TEQ Fish	WHO TEQ Birds	Extraction Recovery	
				Actual	Permitted
	ng	ng	ng	%	%
<b>Dioxins</b>					
2378 Tetra CDD	< 0.003	0.003	0.003	78	50 - 130
12378 Penta CDD	< 0.004	0.004	0.004	66	50 - 130
123478 Hexa CDD	< 0.003	0.0015	0.00015	0	50 - 130
123678 Hexa CDD	< 0.003	0.00003	0.00003	88	50 - 130
123789 Hexa CDD	< 0.003	0.00003	0.00003		
1234678 Hepta CDD	< 0.009	0.000009	0.000009	64	50 - 130
OCDD Octa CDD	< 0.02	-	-	44	20 - 150
<b>Total -Dioxins</b>	<b>0.045</b>	<b>0.008569</b>	<b>0.007219</b>		
<b>Furans</b>					
2378 Tetra CDF	< 0.002	0.0001	0.002	73	50 - 130
12378 Penta CDF	< 0.002	0.0001	0.00002	62	>=50
23478 Penta CDF	< 0.003	0.0015	0.003	0	50 - 130
123478 Hexa CDF	< 0.004	0.0004	0.0004	0	50 - 130
123678 Hexa CDF	< 0.004	0.0004	0.0004	88	50 - 130
234678 Hexa CDF	< 0.004	0.0004	0.0004	0	50 - 130
123789 Hexa CDF	< 0.004	0.0004	0.0004	69	>=50
1234678 Hepta CDF	< 0.004	0.00004	0.00004	69	20 - 150
1234789 Hepta CDF	< 0.005	0.00005	0.00005	0	>=50
OCDF Octa CDF	< 0.01	0.000001	0.000001	0	20 - 150
<b>Total -Furans</b>	<b>0.042</b>	<b>0.0034</b>	<b>0.0067</b>		
<b>Mean Recoveries (%)</b>				<b>70</b>	
<b>Total Isomers</b>	<b>0.087</b>	<b>0.0120</b>	<b>0.0139</b>		
<b>Total ITEQ (&lt;LOD = 0)</b>		<b>0.0000</b>	<b>0.0000</b>		

NOTE: The Total Isomers result includes all isomers below the limit of detection. This gives a "worst case" Dioxins & Furans result.

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**DIOXIN-LIKE PCBs - UPPER LIMIT**

WHO TEQ (Humans / Mammals)					
Test	Sampling Times	Concentration ng/m <sup>3</sup>	LOD ng/m <sup>3</sup>	Limit ng/m <sup>3</sup>	Emission Rate µg/hr
Run 1	07:44 - 13:50 14 September 2016	0.00307	0.00028	-	0.274
Field Blanks Run 1	-	0.00058	-	-	-

WHO TEQ (Fish)					
Test	Sampling Times	Concentration ng/m <sup>3</sup>	LOD ng/m <sup>3</sup>	Limit ng/m <sup>3</sup>	Emission Rate µg/hr
Run 1	07:44 - 13:50 14 September 2016	0.00020	0.00001	-	0.018
Field Blanks Run 1	-	0.00003	-	-	-

WHO TEQ (Birds)					
Test	Sampling Times	Concentration ng/m <sup>3</sup>	LOD ng/m <sup>3</sup>	Limit ng/m <sup>3</sup>	Emission Rate µg/hr
Run 1	07:44 - 13:50 14 September 2016	0.01531	0.00031	-	1.365
Field Blanks Run 1	-	0.00200	-	-	-

Reference conditions are 273K, 101.3kPa without correction for water vapour

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**DIOXIN-LIKE PCBs - LOWER LIMIT**

WHO TEQ (Humans / Mammals)					
Test	Sampling Times	Concentration ng/m <sup>3</sup>	LOD ng/m <sup>3</sup>	Limit ng/m <sup>3</sup>	Emission Rate µg/hr
Run 1	07:44 - 13:50 14 September 2016	0.00307	-	-	0.274
Field Blanks Run 1	-	0.00058	-	-	-

WHO TEQ (Fish)					
Test	Sampling Times	Concentration ng/m <sup>3</sup>	LOD ng/m <sup>3</sup>	Limit ng/m <sup>3</sup>	Emission Rate µg/hr
Run 1	07:44 - 13:50 14 September 2016	0.00020	-	-	0.018
Field Blanks Run 1	-	0.00003	-	-	-

WHO TEQ (Birds)					
Test	Sampling Times	Concentration ng/m <sup>3</sup>	LOD ng/m <sup>3</sup>	Limit ng/m <sup>3</sup>	Emission Rate µg/hr
Run 1	07:44 - 13:50 14 September 2016	0.01531	-	-	1.365
Field Blanks Run 1	-	0.00200	-	-	-

Reference conditions are 273K, 101.3kPa without correction for water vapour



APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**DIOXIN-LIKE PCBs ANALYSIS SUMMARY - RUN 1**

Congener	LOD	Result	WHO TEQ Humans / Mammals	WHO TEQ Fish	WHO TEQ Birds	Recovery
	ng	ng	ng	ng	ng	%
<b>Non-ortho PCBs</b>						
33'44' TCB (77)	0.0041	0.59	0.000059	0.000295	0.059	62
344'5 TCB (81)	0.0027	0.55	0.000165	0.000055	0.0275	56
33'44'5 PeCB (126)	0.016	0.19	0.019	0.00095	0.019	80
33'44'55' HxCB (169)	0.012	0.05	0.00162	0.0000027	0.000054	81
<b>Mono-ortho PCBs</b>						
233'44' PeCB (105)	0.049	3.00	0.00009	0.000015	0.0003	75
2344'5 PeCB (114)	0.023	0.23	0.000069	0.0000115	0.000023	78
23'44'5 PeCB (118)	0.12	8.70	0.000261	0.0000435	0.000087	76
2'344'5 PeCB (123)	0.0026	0.80	0.000024	0.000004	0.000008	85
233'44'5 HxCB (156)	0.016	0.49	0.0000147	0.00000245	0.000049	91
233'44'5' HxCB (157)	0.015	0.14	0.0000042	0.0000007	0.000014	94
23'44'55' HxCB (167)	0.015	0.22	0.0000066	0.0000011	0.0000022	96
233'44'55' HpCB (189)	0.011	0.07	0.00000195	0.000000325	0.00000065	84
<b>Internal Std Recovery</b>						
13C PCB 52	-	-	-	-	-	58
13C PCB 101	-	-	-	-	-	62
13C PCB 118	-	-	-	-	-	48
<b>Mean Analytical Recovery</b>						56
Total PCBs		15.029	0.02125335	0.001370925	0.11	
Reported PCBs (>= or equal to Blank)		15.029	0.02125335	0.001370925	0.11	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**DIOXIN-LIKE PCBs ANALYSIS SUMMARY - BLANK RUN 1**

Congener	LOD	Result	WHO TEQ Humans / Mammals	WHO TEQ Fish	WHO TEQ Birds	Recovery
	ng	ng	ng	ng	ng	%
<b>Non-ortho PCBs</b>						
344'5 TCB (81)	0.0041	0.09	0.0000088	0.000044	0.0088	77
33'44' TCB (77)	0.0027	0.04	0.0000114	0.0000038	0.0019	79
33'44'5 PeCB (126)	0.016	0.03	0.0031	0.000155	0.0031	77
33'44'55' HxCB (169)	0.012	0.03	0.0009	0.0000015	0.00003	64
<b>Mono-ortho PCBs</b>						
233'44' PeCB (105)	0.049	0.15	0.0000045	0.00000075	0.000015	81
2344'5 PeCB (114)	0.023	0.03	0.00000078	0.00000013	0.0000026	82
23'44'5 PeCB (118)	0.12	0.42	0.0000126	0.0000021	0.0000042	79
2'344'5 PeCB (123)	0.0026	0.05	0.00000156	0.00000026	0.00000052	86
233'44'5 HxCB (156)	0.016	0.05	0.00000147	0.000000245	0.0000049	80
233'44'5' HxCB (157)	0.015	0.03	0.00000093	0.000000155	0.0000031	77
23'44'55' HxCB (167)	0.015	0.04	0.00000108	0.00000018	0.00000036	82
233'44'55' HpCB (189)	0.011	0.03	0.00000102	0.00000017	0.00000034	76
<b>Internal Std Recovery</b>						
13C PCB 52	-	-	-	-	-	55
13C PCB 101	-	-	-	-	-	56
13C PCB 118	-	-	-	-	-	56
<b>Mean Analytical Recovery</b>						56
Total PCBs		0.985	0.00404414	0.00020829	0.01	

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS - RUN 1			Dioxins, Furans & PCBs		
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>		
Barometric pressure, P <sub>b</sub>	mm Hg	762.01	CO <sub>2</sub>	%	0.03
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	-3.98	O <sub>2</sub>	%	20.90
$P_s = \frac{P_b + (P_{static})}{13.6}$	mm Hg	761.72	Total	%	20.93
			N <sub>2</sub> (100 -Total)	%	79.07
			$M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2)$		28.84
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			<b>Molecular weight of wet gas, M<sub>s</sub></b>		
Moisture trap weight increase, V <sub>lc</sub>	g	H <sub>2</sub> O by Non Iso	$M_s = M_d(1 - B_{wo}) + 18(B_{wo})$	g/gmol	28.73
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	<b>Velocity of stack gas, V<sub>s</sub></b>		
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			Pitot tube velocity constant, K <sub>p</sub>		
Volume of gas sample through gas meter, V <sub>m</sub>		7.47	34.97		
Gas meter correction factor, Y <sub>d</sub>		1.0135	Velocity pressure coefficient, C <sub>p</sub>		
Mean dry gas meter temperature, T <sub>m</sub>		30.69	0.82		
Mean pressure drop across orifice, DH	mmH <sub>2</sub> O	47.98	Mean of velocity heads, DP <sub>avg</sub> mm H <sub>2</sub> O		
			11.56		
			Mean square root of velocity heads, ÖDP		
			3.40		
			Mean stack gas temperature, T <sub>s</sub> °C		
			34		
			$V_s = \frac{(K_p)(C_p)(\dot{O}DP)(\dot{O}(T_s + 273))}{(M_s)(P_s)}$		
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (DH/13.6))(Y_d)}{T_m + 273}$		6.85	11.55		
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			<b>Absolute flow of stack gas, Q<sub>a</sub></b>		
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	6.9259	Area of stack, A <sub>s</sub> m <sup>2</sup>		
			2.41		
			$Q_a = (60)(A_s)(V_s)$		
			m <sup>3</sup> /min		
			1666.6		
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O<sub>2</sub></sub></b>			<b>Total flow of stack gas, Q</b>		
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)	No		Conversion factor (K/mm.Hg)		
% oxygen measured in gas stream, act%O <sub>2</sub>	20.90		Q <sub>std</sub> = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})}{(T_s) + 273}$		
% oxygen reference condition	21		Dry		
O <sub>2</sub> Reference	O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>	No O2 Ref	Q <sub>std@O<sub>2</sub></sub> = $\frac{(Q_a)P_s(0.3592)(1-B_{wo})(O_2REF)}{(T_s) + 273}$		
Factor	21.0 - ref%O <sub>2</sub>	No O2 Ref	@O2ref		
			No O2 Ref		
$V_{mstd@X\%oxygen} = (V_{mstd})(O_2 Ref)$	m <sup>3</sup>	No O2 Ref	Q <sub>stw</sub> = $\frac{(Q_a)P_s(0.3592)}{(T_s) + 273}$		
			Wet		
			1486		
<b>Moisture content, B<sub>wo</sub></b>			<b>Percent isokinetic, %I</b>		
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	0.0103	Nozzle diameter, D <sub>n</sub> mm		
		1.03	6.2		
			Nozzle area, A <sub>n</sub> mm <sup>2</sup>		
			30.4		
			Total sampling time, q min		
			360.0		
			$\%I = \frac{(4.6398E6)(T_s + 273)(V_{mstd})}{(P_s)(V_s)(A_n)(q)(1 - B_{wo})}$		
			102.5		
<b>Moisture by FTIR</b>	%	-	Acceptable isokinetic range 95% to 115%		
			Yes		

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**DIOXINS & FURANS & PCBs QUALITY ASSURANCE CHECKLIST**

Leak Test Results	Mean Sampling Rate litre/min	Pre-sampling Leak Rate litre/min	Post-sampling Leak Rate litre/min	Maximum Vacuum mm Hg	Acceptable Leak Rate litre/min	Leak Tests Acceptable litre/min
Run 1	21.03	0.24	0.24	-406.4	1.05	Yes

Isokinetic Criterion Compliance	Isokinetic Variation %	Acceptable Isokineticity
Run 1	102.5	Yes

Acceptable isokinetic range 95% to 115%

Filtration	Filter Material	Filter Size mm	Maximum Filtration Temperature °C
Run 1	QF	90	120

GF = Glass Fibre

QF = Quartz Fibre

Critical Sampling Requirement	Maximum Temperature at Condenser / Adsorber °C	Maximum Temperature during storage / transit °C	Acceptable Temperature?
Run 1	15	22	Yes

Acceptable < 25°C

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**HEAVY METALS SOLID & VAPOUR PHASES COMBINED**

CADMIUM & THALLIUM COMBINED					
Test	Sampling Times	Concentration mg/m <sup>3</sup>	LOD mg/m <sup>3</sup>	Limit mg/m <sup>3</sup>	Emission Rate g/hr
Run 1	08:00 - 09:34 15 September 2016	0.0009	0.0006	1.00	0.08
Field Blank	-	0.0007	-	-	-
TOTAL HEAVY METALS COMBINED					
Test	Sampling Times	Concentration mg/m <sup>3</sup>	LOD mg/m <sup>3</sup>	Limit mg/m <sup>3</sup>	Emission Rate g/hr
Run 1	08:00 - 09:34 15 September 2016	12.8170	0.0053	32	1178.12
Field Blank	-	0.0401	-	-	-

Reference conditions are 273K, 101.3kPa without correction for water vapour

**INDIVIDUAL METALS SUMMARY - SOLID & VAPOUR PHASES COMBINED**

Metals	LOD mg/m <sup>3</sup>	Concentration mg/m <sup>3</sup>	Emission Rate g/hr
Cadmium	0.00031	0.00047	0.0437
Thallium	0.00036	0.00039	0.0357
Cadmium & Thallium	0.00065	0.00086	0.0794

Metals	LOD mg/m <sup>3</sup>	Concentration mg/m <sup>3</sup>	Emission Rate g/hr
Arsenic	0.00044	0.00069	0.0632
Antimony	0.00025	0.00043	0.0398
Chromium	0.00024	0.01067	0.9811
Cobalt	0.00014	0.00020	0.0182
Copper	0.00031	0.29755	27.350
Lead	0.00031	0.52941	48.662
Manganese	0.00028	0.00862	0.7923
Nickel	0.00028	0.01690	1.5532
Tin	0.00019	0.00041	0.0379
Vanadium	0.00163	0.00213	0.1956
Zinc	0.00128	11.9500	1098
Total Other Heavy Metals	0.00534	12.8170	1178

Reference conditions are 273K, 101.3kPa without correction for water vapour

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**HEAVY METALS - RUN 1 SUMMARY**

Metals	PARTICULATE PHASE			VAPOUR PHASE		
	Stack LOD mg/m <sup>3</sup>	Laboratory Result ug	Concentration mg/m <sup>3</sup>	Stack LOD mg/m <sup>3</sup>	Laboratory Result ug	Concentration mg/m <sup>3</sup>
Cadmium	0.00	0.50	0.00	0.00	0.34	0.00
Thallium	0.00	0.60	0.00	0.00	0.09	0.00
Cadmium & Thallium	0.00	1.10	0.00	0.00	0.43	0.00
Volume Sampled m <sup>3</sup>			1.7700			1.7700

Reference conditions are 273K, 101.3kPa without correction for water vapour

Metals	PARTICULATE PHASE			VAPOUR PHASE		
	Stack LOD mg/m <sup>3</sup>	Laboratory Result ug	Concentration mg/m <sup>3</sup>	Stack LOD mg/m <sup>3</sup>	Laboratory Result ug	Concentration mg/m <sup>3</sup>
Arsenic	0.00034	0.80000	0.00045	0.00010	0.41630	0.00024
Antimony	0.00023	0.40000	0.00023	0.00002	0.36590	0.00021
Chromium	0.00017	3.50000	0.00198	0.00007	15.39200	0.00870
Cobalt	0.00011	0.20000	0.00011	0.00002	0.15140	0.00009
Copper	0.00028	510.00000	0.28814	0.00002	16.65600	0.00941
Lead	0.00028	930.00000	0.52543	0.00002	7.04080	0.00398
Manganese	0.00023	9.20000	0.00520	0.00005	6.05680	0.00342
Nickel	0.00023	21.00000	0.01186	0.00005	8.90860	0.00503
Tin	0.00017	0.30000	0.00017	0.00002	0.42900	0.00024
Vanadium	0.00113	2.00000	0.00113	0.00050	1.76600	0.00100
Zinc	0.00028	21000.00000	11.86458	0.00100	151.16800	0.08541
Total Other Heavy Metals	0.00345	22477.40000	12.69929	0.00190	208.35080	0.11771
Volume Sampled m <sup>3</sup>			1.7700			1.7700

Reference conditions are 273K, 101.3kPa without correction for water vapour

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**HEAVY METALS - BLANK SUMMARY**

Metals	PARTICULATE PHASE			VAPOUR PHASE		
	Stack LOD mg/m <sup>3</sup>	Laboratory Result ug	Concentration mg/m <sup>3</sup>	Stack LOD mg/m <sup>3</sup>	Laboratory Result ug	Concentration mg/m <sup>3</sup>
Cadmium	0.00028	0.5	0.00028	0.00002	0.04460	0.00003
Thallium	0.00028	0.6	0.00034	0.00002	0.04460	0.00003
Cadmium & Thallium	0.00056	1.1	0.00062	0.00002	0.08920	0.00005
Volume Sampled m <sup>3</sup>			1.7700			1.7700

Reference conditions are 273K, 101.3kPa without correction for water vapour

Metals	PARTICULATE PHASE			VAPOUR PHASE		
	Stack LOD mg/m <sup>3</sup>	Laboratory Result ug	Concentration mg/m <sup>3</sup>	Stack LOD mg/m <sup>3</sup>	Laboratory Result ug	Concentration mg/m <sup>3</sup>
Arsenic	0.00034	0.60000	0.00034	0.00010	0.17840	0.00010
Antimony	0.00023	0.40000	0.00023	0.00002	0.04460	0.00003
Chromium	0.00017	1.00000	0.00056	0.00007	0.13380	0.00008
Cobalt	0.00011	0.20000	0.00011	0.00002	0.04460	0.00003
Copper	0.00028	2.00000	0.00113	0.00002	0.53520	0.00030
Lead	0.00028	2.00000	0.00113	0.00002	0.04460	0.00003
Manganese	0.00023	0.90000	0.00051	0.00005	0.08920	0.00005
Nickel	0.00023	2.00000	0.00113	0.00005	0.08920	0.00005
Tin	0.00017	20.00000	0.01130	0.00002	0.04460	0.00003
Vanadium	0.00113	2.00000	0.00113	0.00050	0.89200	0.00050
Zinc	0.00028	36.00000	0.02034	0.00100	1.78400	0.00101
Total Other Heavy Metals	0.00345	67.10000	0.03791	0.00190	3.88020	0.00219
Volume Sampled m <sup>3</sup>			1.7700			1.7700

Reference conditions are 273K, 101.3kPa without correction for water vapour

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS RUN 1			Cd, Tl & Heavy Metals		
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>		
Barometric pressure, P <sub>b</sub>	mm Hg	766.5	CO <sub>2</sub>	%	0.03
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	-4.0	O <sub>2</sub>	%	20.90
$P_s = \frac{P_b + (P_{static})}{13.6}$	mm Hg	766.2	Total	%	20.93
			N <sub>2</sub> (100 -Total)	%	79.07
			$M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2)$		28.84
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			<b>Molecular weight of wet gas, M<sub>s</sub></b>		
Moisture trap weight increase, V <sub>lc</sub>	g	H <sub>2</sub> O by Non Iso	$M_s = M_d(1 - B_{wo}) + 18(B_{wo})$	g/gmol	28.73
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	-	<b>Velocity of stack gas, V<sub>s</sub></b>		
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			Pitot tube velocity constant, K <sub>p</sub>		
Volume of gas sample through gas meter, V <sub>m</sub>		1.883	Velocity pressure coefficient, C <sub>p</sub>		34.97
Gas meter correction factor, Y <sub>d</sub>		1.0135	Mean of velocity heads, DP <sub>avg</sub>	mm H <sub>2</sub> O	0.82
Mean dry gas meter temperature, T <sub>m</sub>		28.42	Mean square root of velocity heads, ÖDP		12.08
Mean pressure drop across orifice, DH	mm	50.33	Mean stack gas temperature, T <sub>s</sub>	°C	31
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (DH/13.6))(Y_d)}{T_m + 273}$		1.75	$V_s = \frac{(K_p)(C_p)(\sqrt{DP})(\sqrt{T_s + 273})}{(M_s)(P_s)}$	m/s	11.70
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			<b>Actual flow of stack gas, Q<sub>a</sub></b>		
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	1.7700	Area of stack, A <sub>s</sub>	m <sup>2</sup>	2.41
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O<sub>2</sub></sub></b>			$Q_a = (60)(A_s)(V_s)$		
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)	No		<b>Total flow of stack gas, Q</b>		
% oxygen measured in gas stream, act%O <sub>2</sub>	20.9		Conversion factor (K/mm.Hg)		0.3592
% oxygen reference condition	21		$Q_{std} = \frac{(Q_a)P_s(0.3592)(1 - B_{wo})}{(T_s) + 273}$	Dry	1516.1
O <sub>2</sub> Reference	O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>	No O <sub>2</sub> Ref	$Q_{std@O_2} = \frac{(Q_a)P_s(0.3592)(1 - B_{wo})(O_2REF)}{(T_s) + 273}$	@O <sub>2</sub> ref	No O <sub>2</sub> Ref
Factor	21.0 - ref%O <sub>2</sub>		$Q_{stw} = \frac{(Q_a)P_s(0.3592)}{(T_s) + 273}$	Wet	1532.0
$V_{mstd@X\%oxygen} = (V_{mstd})(O_2 Ref)$	m <sup>3</sup>	No O <sub>2</sub> Ref	<b>Percent isokinetic, %I</b>		
<b>Moisture content, B<sub>wo</sub></b>			Nozzle diameter, D <sub>n</sub>		
$B_{wo} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	0.0103	Nozzle area, A <sub>n</sub>	mm <sup>2</sup>	6.22
		1.03	Total sampling time, q	min	30.39
<b>Moisture by FTIR</b>			$\%I = \frac{(4.6398E6)(T_s + 273)(V_{mstd})}{(P_s)(V_s)(A_n)(q)(1 - B_{wo})}$		
		-	Acceptable isokinetic range 95% to 115%		
			Yes		



APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**HEAVY METALS QA CHECKLIST**

Leak Test Results	Mean Sampling Rate litre/min	Pre-sampling Leak Rate litre/min	Post-sampling Leak Rate litre/min	Maximum Vacuum mm Hg	Acceptable Leak Rate litre/min	Leak Tests Acceptable litre/min
Run 1	21.2	0.26	0.30	-406.4	0.42	Yes

Isokinetic Criterion Compliance	Isokinetic Variation %	Acceptable Isokineticity
Run 1	101.6	Yes

Filtration / Temp	Filter Material	Filter Size mm	Maximum Filtration Temperature °C	Maximum storage / transit Temperature °C
Run 1	QF	90	180	22

GF = Glass Fibre  
QF = Quartz Fibre

Metals	Type of Absorbers - Metals	Absorption Solutions - Metals
Run 1	Glass	3.3% Nitric Acid, 1.5% Hydrogen Peroxide

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**HEAVY METALS ABSORPTION EFFICIENCY**

Parameter		Total ug	3rd Absorber ug	Absorption Efficiency (%)	Required %	Pass / Fail
Cadmium	Run 1	0.84070	0.03	97	90	N/A <30% ELV
Thallium	Run 1	1.52900	0.03	98	90	N/A <30% ELV
Arsenic	Run 1	1.21630	0.10	92	90	Pass
Antimony	Run 1	0.76590	0.05	93	90	Pass
Chromium	Run 1	18.89200	2.77	85	90	Fail
Cobalt	Run 1	0.35140	0.03	93	90	Pass
Copper	Run 1	526.65600	1.51	100	90	Pass
Lead	Run 1	937.04080	0.73	100	90	Pass
Manganese	Run 1	15.25680	0.50	97	90	Pass
Nickel	Run 1	29.90860	0.71	98	90	Pass
Tin	Run 1	0.72900	0.05	93	90	Pass
Vanadium	Run 1	3.76600	0.50	87	90	Fail
Zinc	Run 1	21151.16800	12.35	100	90	Pass

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

HYDROGEN FLUORIDE SUMMARY					
Test	Sampling Times	Concentration mg/m <sup>3</sup>	LOD mg/m <sup>3</sup>	Limit mg/m <sup>3</sup>	Emission Rate g/hr
Run 1	07:50 - 13:50 14 September 2016	<b><i>0.02</i></b>	0.00	5	<b><i>1.57</i></b>
Field Blank	-	0.008049997	-	-	-

Please note figures in bold italic font are at the limit of detection

Reference conditions are 273K, 101.3kPa without correction for water vapour

**HYDROGEN FLUORIDE QUALITY ASSURANCE CHECKLIST**

Leak Test Results	Mean Sampling Rate	Pre sampling leak rate	Post sampling leak rate	Acceptable leak rate	Leak Tests Acceptable?
	l/min	l/min	l/min	l/min	
Run 1	2.5	0.02	0.02	0.05	Yes

	Filter Material	Filter Size mm	Max. Filtration Temp. °C	Max. Storage / Transit Temp. °C	Type of Absorbers	Absorption Solutions
Run 1	Quartz	47	31	23	Quartz	0.1N Sodium Hydroxide

GF = Glass Fibre

QF = Quartz Fibre

**HYDROGEN FLUORIDE ABSORPTION EFFICIENCY**

Parameter	Total ug	IMP C ug	Absorption Efficiency %	Acceptable Absorption Efficiency %	Absorption Efficiency Acceptable ?
Run 1	ND	ND	100	95	Yes

ND - None Detected

### MOISTURE CALCULATIONS

Moisture Determination - Non Isokinetic							
Test Number	Sampling Time and Date	Start Weight	End Weight	Total gain	Concentration	LOD	Uncertainty
		kg	kg	kg	%	%	%
Run 1	07:44 - 13:50 14 September 2016	4.3441	4.4070	0.0629	1.0	0.00	2.9

Moisture Quality Assurance							
Test Number	Sampling Duration	Total Volume Sampled	Sampling Rate	Start Leak Rate	End Leak Rate	Acceptable Leak Rate	Leak Tests Acceptable?
	mins	l	l/min	l/min	l/min	l/min	
Run 1	360	7499	20.8	0.240	0.260	0.417	Yes

### PRELIMINARY STACK SURVEY

Stack Characteristics		
Stack Diameter / Depth, D	1.75	m
Stack Width, W	-	m
Stack Area, A	2.41	m <sup>2</sup>
Average stack gas temperature	30	°C
Stack static pressure	-0.039	kPa
Barometric Pressure	101.6	kPa

Stack Gas Composition & Molecular Weights								
Component	Molar Mass M	Density kg/m <sup>3</sup> p	Conc Dry % Vol	Dry Volume Fraction r	Dry Conc kg/m <sup>3</sup> pi	Conc Wet % Vol	Wet Volume Fraction r	Wet Conc kg/m <sup>3</sup> pi
CO <sub>2</sub>	44	1.963059	0.030000	0.000300	0.000589	0.029690	0.000297	0.000583
O <sub>2</sub>	32	1.427679	20.900000	0.209000	0.298385	20.683826	0.206838	0.295299
N <sub>2</sub>	28	1.249219	79.070000	0.790700	0.987758	78.252159	0.782522	0.977541
H <sub>2</sub> O	18	0.803070	-	-	-	1.034325	0.010343	0.008306

Where:  $p = M / 22.41$      $pi = r \times p$

Calculation of Stack Gas Densities		
Determinand	Result	Units
Dry Density (STP), $P_{STD}$	1.2867	kg/m <sup>3</sup>
Wet Density (STP), $P_{STW}$	1.2817	kg/m <sup>3</sup>
Dry Density (Actual), $P_{Actual}$	1.1633	kg/m <sup>3</sup>
Average Wet Density (Actual), $P_{ActualW}$	1.159	kg/m <sup>3</sup>

Where:

$P_{STD}$  = sum of component concentrations, kg/m<sup>3</sup> (not including water vapour)

$P_{STW} = (P_{STD} + pi \text{ of H}_2\text{O}) / (1 + (pi \text{ of H}_2\text{O} / 0.8036))$

$P_{Actual} = P_{STD} \times (Ts / Ps) \times (Pa / Ta)$

$P_{ActualW} = P_{STW} \times (Ts / Ps) \times (Pa / Ta)$

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY**

**TRAVERSE 1**

Date of Survey	14 September 2016
Time of Survey	07:30
Velocity Measurement Device:	S-Type Pitot

Sampling Line A								
Traverse Point	Distance into duct (m)	DP pt mmH <sub>2</sub> O (average of 3 readings)	DP pt Pa (average of 3 readings)	Temp °C	Velocity m/s	Volumetric Flow Rate (actual) m <sup>3</sup> /s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.08	12.6	124	29	11.95	28.75	-	<15
2	0.26	13.8	135	29	12.47	30.01	-	<15
3	0.52	14.1	138	30	12.65	30.42	-	<15
4	1.23	13.7	135	30	12.48	30.02	-	<15
5	1.49	13.4	131	30	12.33	29.66	-	<15
6	1.67	12.9	127	30	12.11	29.14	-	<15
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
Mean	-	13.4	132	30	12.33	29.67	-	-

Sampling Line B								
Traverse Point	Distance into duct (m)	DP pt mmH <sub>2</sub> O (average of 3 readings)	DP pt Pa (average of 3 readings)	Temp °C	Velocity m/s	Volumetric Flow Rate (actual) m <sup>3</sup> /s	O <sub>2</sub> % Vol	Angle of Swirl °
1	-	12.9	127	30	12.11	29.14	-	<15
2	-	13.4	131	30	12.33	29.66	-	<15
3	-	13.7	134	29	12.44	29.94	-	<15
4	-	14.1	138	30	12.63	30.38	-	<15
5	-	14.3	140	30	12.74	30.64	-	<15
6	-	13.5	133	30	12.39	29.80	-	<15
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
Mean	-	13.7	134	30	12.44	29.93	-	-

**PRELIMINARY STACK SURVEY QUALITY ASSURANCE CHECKLIST**

PITOT LEAK CHECK								
Run	Pre Traverse Leak Rate				Post Traverse Leak Rate			
	Start Value mmH <sub>2</sub> O	End Value mmH <sub>2</sub> O	Difference %	Outcome	Start Value mmH <sub>2</sub> O	End Value mmH <sub>2</sub> O	Difference %	Outcome
Run 1	90	88	2.2	Pass	92	90	2.2	Pass

To complete a compliant pitot leak check a pressure of over 80 mmH<sub>2</sub>O (or 800 Pa) is applied and the pressure drop monitored over 5 mins. A drop of ≤ 5% must be observed.

S-Type Pitot Stagnation Check				
Run	Stagnation (Pa)	Reference (Pa)	Difference (Pa)	Outcome (Permitted +/- 10 Pa)
Run 1	-39	-39	0.0	Pass

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

Sampling Plane Validation Criteria				
EA Technical Guidance Note (Monitoring) M1	Result	Units	Requirement	Compliant
Lowest Differential Pressure	123.81	Pa	>= 5 Pa	Yes
Lowest Gas Velocity	11.95	m/s	-	-
Highest Gas Velocity	12.74	m/s	-	-
Ratio of Gas Velocities	1.07	-	< 3 : 1	Yes
Maximum angle of flow with regard to duct axis	0	°	< 15°	Yes
No local negative flow	Yes	-	-	Yes

Calculation of Stack Gas Velocity, V		
Velocity at Traverse Point, $V = K_{pt} \times (1-e) \times \sqrt{2 \times DP_{pt} / \rho_{ActualW}}$		
<b>Where:</b>		
$K_{pt}$ = Pitot tube calibration coefficient		
(1-e) = Compressibility correction factor, assumed at a constant 0.998		
Average Stack Gas Velocity, $V_a$	12.39	m/s

Calculation of Stack Gas Volumetric Flowrate, Q			
Duct gas flow conditions	Actual	Reference	Units
Temperature	30	0	°C
Total Pressure	101.561	101.3	kPa
Oxygen	20.9	21	%
Moisture	1.03	1.03	%
Pitot tube calibration coefficient, $K_{pt}$	0.82		

Gas Volumetric Flowrate	Result	Units
Average Stack Gas Velocity ( $V_a$ )	12.39	m/s
Stack Area (A)	2.41	m <sup>2</sup>
Gas Volumetric Flowrate (Actual), $Q_{Actual}$	107263	m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Wet), $Q_{STP}$	96972	m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Dry), $Q_{STP,Dry}$	95969	m <sup>3</sup> /hr
Gas Volumetric Flowrate (REF), $Q_{Ref}$	96972	m <sup>3</sup> /hr

**Where:**

$$Q_{Actual} = V_a \times A \times 3600$$

$$Q_{STP} = Q (Actual) \times (T_s / T_a) \times (P_a / P_s) \times 3600$$

$$Q_{STP,Dry} = Q (STP) / (100 - (100 / Ma)) \times 3600$$

$$Q_{Ref} = Q (STP) \times ((100 - Ma) / (100 - Ms)) \times ((20.9 - O_{2a}) / (20.9 - O_{2s}))$$

**Nomenclature:**

$T_s$  = Absolute Temperature, Standard Conditions, 273 K

$P_s$  = Absolute Pressure, Standard Conditions, 101.3 kPa

$T_a$  = Absolute Temperature, Actual Conditions, K

$P_a$  = Absolute Pressure, Actual Conditions, kPa

$Ma$  = Water vapour, Actual Conditions, % Vol

$Ms$  = Water vapour, Reference Conditions, % Vol

$O_{2a}$  = Oxygen, Actual Conditions, % Vol

$O_{2s}$  = Oxygen, Reference Conditions, % Vol


APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**STACK DIAGRAM**

	Value	Units
Stack Depth	1.75	m
Stack Width	-	m
Area	2.41	m <sup>2</sup>

Non-Isokinetic/Gases Sampling			
Sampling Point	Distance (% of Depth)	Distance into Stack (m)	Units
-	-	-	-

Isokinetic Sampling			
Sampling Point	Distance (% of Depth)	Distance into Stack (m)	Swirl °
1	4.4	0.08	< 15
2	14.6	0.26	< 15
3	29.5	0.52	< 15
4	4.4	0.08	< 15
5	14.6	0.26	< 15
6	29.5	0.52	< 15
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-



**SAMPLING LOCATION**



APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - TOTAL PARTICULATE MATTER**

Run	Sampled Volume m <sup>3</sup>	Sampled Gas Temp K	Sampled Gas Pressure kPa	Sampled Gas Humidity % by volume	Oxygen Content % by volume	Limit of Detection % by mass	Leak %	Uncollected Mass mg
<b>MU required</b>	<b>≤ 2%</b>	<b>≤ 2%</b>	<b>≤ 1%</b>	<b>≤ 1%</b>	<b>≤ 10%</b>	<b>≤ 5% of ELV</b>	<b>≤ 2%</b>	<b>≤ 10% of ELV</b>
Run 1	0.001	2	0.5	1	N/A	0.5000	-	-
as a %	0.06	0.65	0.49	1.00	N/A	1.50522	1.17	0.003
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>

Run	Volume (STP) m <sup>3</sup>	Mass of particulate mg	O <sub>2</sub> Correction -	Leak mg/m <sup>3</sup>	Uncollected Mass mg	Combined uncertainty
Run 1	1.47	18.4000	1.00	0.075	0.0003	-
MU as mg/m <sup>3</sup>	0.14	0.3010	-	0.075	0.0002	<b>0.34</b>
MU as %	1.29	2.7174	-	0.676	0.0016	-

<b>R1 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.68</b>	<b>mg/m<sup>3</sup></b>	<b>6.17</b>	<b>%</b>
---	-------------	-------------------------	-------------	----------

(k is a coverage factor which gives a 95% confidence in the quoted figures)  
Developed for the STA by R Robinson, NPL



APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - DIOXINS & FURANS**

Run	Sampled Volume m <sup>3</sup>	Sampled Gas Temp K	Sampled Gas Pressure kPa	Sampled Gas Humidity % by volume	Oxygen Content % by volume	Leak %
<b>MU required</b>	≤ 2%	≤ 2%	≤ 1%	≤ 1%	≤ 10%	≤ 2%
Run 1	0.001	2	0.5	1	N/A	-
as a %	0.01	0.66	0.49	1.00	N/A	1.14
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>

Run	Volume (STP) m <sup>3</sup>	O2 Correction	Leak ng/m <sup>3</sup>	Laboratory analysis	Combined uncertainty
Run 1	6.2421	1.0000	0.0001	-	-
MU as ng/m <sup>3</sup>	0.0002	-	0.0001	0.0014	<b>0.0014</b>
MU as %	1.2947	-	0.6590	10.00	-

<b>R1 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.003</b>	<b>ng/m<sup>3</sup></b>	<b>20.2</b>	<b>%</b>
---	--------------	-------------------------	-------------	----------

(k is a coverage factor which gives a 95% confidence in the quoted figures)  
Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - PCBs**

Run	Sampled Volume m <sup>3</sup>	Sampled Gas Temp K	Sampled Gas Pressure kPa	Sampled Gas Humidity % by volume	Oxygen Content % by volume	Leak %	Uncollected Mass ng/m <sup>3</sup>
<b>MU required</b>	≤ 2%	≤ 2%	≤ 1%	≤ 1%	≤ 10%	≤ 2%	≤ 10% ELV
Run 1	0.001	2	1	1	N/A	-	-
as a %	0.01	0.66	0.98	1.00	N/A	1.42	N/A
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>	<b>N/A</b>

Run	Volume (STP) m <sup>3</sup>	O2 Correction	Leak ng/m <sup>3</sup>	Uncollected Mass ng/m <sup>3</sup>	Laboratory analysis	Combined uncertainty
Run 1	6.2421	1.0000	0.0000	0.1654	-	-
MU as ng/m <sup>3</sup>	0.0000	0.0000	0.0000	0.0000338	0.0003	<b>0.0004</b>
MU as %	1.5503	-	0.8195	1.1002	10.00	-

<b>R1 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.0007</b>	<b>ng/m<sup>3</sup></b>	<b>24</b>	<b>%</b>
---	---------------	-------------------------	-----------	----------

(k is a coverage factor which gives a 95% confidence in the quoted figures)  
Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - CADMIUM & THALLIUM**

Run	Sampled Volume m <sup>3</sup>	Sampled Gas Temp K	Sampled Gas Pressure kPa	Sampled Gas Humidity % by volume	Oxygen Content % by volume	Concentration in impinger mg	Leak %
<b>MU required</b>	<b>&lt;=2%</b>	<b>&lt;2.5 k</b>	<b>&lt;=1%</b>	<b>&lt;=1%</b>	<b>&lt;=5%</b>	<b>&lt;5%</b>	<b>&lt;=2%</b>
Run 1	0.001	2.0	0.5	1	0.1	0.00	-
as a %	0.06	0.66	0.49	1.00	-	3.00	1.41
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>	<b>Yes</b>

Run	Volume (STP) m <sup>3</sup>	O2 Correction	Leak mg/m <sup>3</sup>	Lab Uncertainty mg	Combined uncertainty
Run 1	1.6112	-	0.0000	-	-
MU as mg	0.0000	-	0.0000	0.00010	<b>0.0001</b>
MU as %	1.2982	-	0.8168	11.30000	-

<b>R1 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.00</b>	<b>mg/m<sup>3</sup></b>	<b>22.81</b>	<b>%</b>
---	-------------	-------------------------	--------------	----------

(k is a coverage factor which gives a 95% confidence in the quoted figures)  
Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - HEAVY METALS**

Run	Sampled Volume m <sup>3</sup>	Sampled Gas Temp K	Sampled Gas Pressure kPa	Sampled Gas Humidity % by volume	Oxygen Content % by volume	Concentration in impinger mg	Leak %
<b>MU required</b>	<b>&lt;=2%</b>	<b>&lt;2.5 k</b>	<b>&lt;=1%</b>	<b>&lt;=1%</b>	<b>&lt;=5%</b>	<b>&lt;5%</b>	<b>&lt;=2%</b>
Run 1	0.001	2.00	0.50	1.00	0.10	0.01	-
as a %	0.06	0.73	0.49	1.00	-	3.00	1.41
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>	<b>Yes</b>

Run	Volume (STP) m <sup>3</sup>	O2 Correction	Leak mg/m <sup>3</sup>	Lab Uncertainty mg	Combined uncertainty
Run 1	1.7789	-	0.1047	-	-
MU as mg/m <sup>3</sup>	0.1711	-	0.1047	1.44832	<b>1.4621</b>
MU as %	1.3346	-	0.8168	11.30000	-

<b>R1 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>2.92</b>	<b>mg/m<sup>3</sup></b>	<b>22.82</b>	<b>%</b>
---	-------------	-------------------------	--------------	----------

(k is a coverage factor which gives a 95% confidence in the quoted figures)  
Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - NON-ISOKINETIC HYDROGEN FLUORIDE**

Run	Sampled Volume m <sup>3</sup>	Sampled Gas Temp K	Sampled Gas Pressure kPa	Sampled Gas Humidity % by volume	Oxygen Content % by volume	Concentration in iminger mg	Limit of Detection % by mass	Leak %
<b>MU required</b>	<b>&lt;=2%</b>	<b>&lt;2.5 k</b>	<b>&lt;=1%</b>	<b>&lt;=1%</b>	<b>&lt;=5%</b>	<b>&lt;5%</b>	<b>≤ 5% of ELV</b>	<b>&lt;=2%</b>
Run 1	0.000	2.000	0.500	1.000	0.100	0.001	0.000	-
as a %	0.005	0.676	0.492	1.000	-	3.000	3.007	0.797
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>

Run	Volume (STP) m <sup>3</sup>	Mass of Hydrogen Fluoride mg	O2 Correction -	Leak mg/m <sup>3</sup>	Lab Uncertainty mg	Combined uncertainty
Run 1	0.8446	0.0148	-	0.0001	-	-
MU as mg/m <sup>3</sup>	0.0002	0.0005	-	0.0001	0.0005	<b>0.0007</b>
MU as %	1.3034	3.0068	-	0.4600	3.1	-

<b>R1 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.00</b>	<b>mg/m<sup>3</sup></b>	<b>9.00</b>	<b>%</b>
---	-------------	-------------------------	-------------	----------

(k is a coverage factor which gives a 95% confidence in the quoted figures)  
Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - MOISTURE**

Run	Sampled Volume m <sup>3</sup>	Sampled Gas Temp K	Sampled Gas Pressure kPa	Sampled Gas Humidity % by volume	Oxygen Content % by volume	Leak %
<b>MU required</b>	<b>≤ 2%</b>	<b>≤ 2%</b>	<b>≤ 1%</b>	<b>≤ 1%</b>	<b>≤ 10%</b>	<b>≤ 2%</b>
Run 1	0.000	2	0.5	1	N/A	-
as a %	0.01	0.66	0.49	1.00	N/A	1.15
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>

Run	Volume (STP) m <sup>3</sup>	Mass Gained mg	O2 Correction -	Leak mg/m <sup>3</sup>	Uncollected Mass mg	Combined uncertainty
Run 1	6.8	62900.0	1.00	55.8	57.7	-
MU as % v/v	0.01	0.00	-	0.01	0.00	<b>0.02</b>
MU as %	1.3	0.2	-	0.7	0.1	-

<b>R1 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.03</b>	<b>% v/v</b>	<b>2.94</b>	<b>%</b>
---	-------------	--------------	-------------	----------

Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - VELOCITY & VOLUMETRIC FLOW RATE**

Measured Velocity at Actual Conditions	12.4	m/s
Measured Volumetric Flow rate at Actual Conditions	107263	m <sup>3</sup> /hr

Performance Characteristics & Source of Value	Units	Values	Requirement	Compliant
<b>Uncertainty of Local Gas Velocity Determination</b>				
Uncertainty of pitot tube coefficient	-	0.010		
Uncertainty of mean local dynamic pressures	-	0.37		
Factor loading, function of the number of measurements.	3 readings	0.591	minimum 3	Yes
Range of measurement device	pa	1000		
Resolution	pa	1.00		
Calibration uncertainty	pa	3.91	<1% of Value or 20 Pa whichever is greater	Yes
Drift	% range	0.10		
Linearity	% range	0.06	<2% of value	Yes
Uncertainty of gas density determination				
Uncertainty of molar mass determination	kg/mol	0.00003		
Uncertainty of temperature measurement	K	1.54	<1% of value	Yes
Uncertainty of absolute pressure in the duct	pa	518		
Uncertainty associated with the estimate of density	-	0.007		
Uncertainty associated with the measurement of local velocity	-	0.0001		
Uncertainty associated with the measurement of mean velocity	-	0.0002		

Measurement Uncertainty - Velocity	m/s
Combined uncertainty	0.16
Expanded uncertainty at a 95% Confidence Interval	0.31

Note - The expanded uncertainty uses a coverage factor of k = 2.

Expanded Measurement Uncertainty of Velocity at a 95% Confidence Interval	%
Expressed as a % of the Measured Concentration	1.27
Expanded uncertainty at a 95% Confidence Interval	2.49

Measurement Uncertainty Volumetric Flow Rate	m <sup>3</sup> /hr
Combined uncertainty	2827.94
Expanded uncertainty at a 95% Confidence Interval	5542.76

Note - The expanded uncertainty uses a coverage factor of k = 2.

Expanded Measurement Uncertainty of Volumetric Flow Rate at a 95% Confidence Interval	%
Expressed as a % of the Measured Concentration	2.64
Expanded uncertainty at a 95% Confidence Interval	5.17

END OF REPORT

# STACK EMISSIONS MONITORING REPORT



Unit D  
 Bankside Trade Park  
 Cirencester  
 GL7 1YT  
 Tel: 01285 700 593

Your contact at ESG
Mike Davies Business Manager - South Tel: 07976 297465 Email: mike.davies@esg.co.uk

Operator & Address:
Bolton Aerospace Limited PO Box 22 Hadleigh Road Ipswich Suffolk IP2 0EG

Permit:
EPR Permit: EP54/1/LB

Release Point:
A8 - Ball Mill

Sampling Date(s):
13 September 2016

ESG Job Number:	LSO 160910
Report Date:	25th October 2016
Version:	1
Report By:	Owen May
MCERTS Number:	MM 10 1072
MCERTS Level:	MCERTS Level 2 - Team Leader
Technical Endorsements:	1, 2, 3 & 4
Report Approved By:	Mike Davies
MCERTS Number:	MM 02 087
Business Title:	MCERTS Level 2 - Business Manager
Technical Endorsements:	1, 2, 3 & 4
Signature:	



1015



## CONTENTS

### EXECUTIVE SUMMARY

#### Stack Emissions Monitoring Objectives

- Plant
- Operator
- Stack Emissions Monitoring Test House

#### Emissions Summary

##### Monitoring Times

##### Process Details

##### Monitoring Methods

##### Analytical Methods

- Sampling Methods with Subsequent Analysis
- On-Site Testing

##### Sampling Location

- Sampling Plane Validation Criteria
- Duct Characteristics
- Sampling Lines & Sample Points
- Sampling Platform
- Sampling Location / Platform Improvement Recommendations

##### Sampling and Analytical Method Deviations

### APPENDICES

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

APPENDIX 3 - Measurement Uncertainty Budget Calculations

## EXECUTIVE SUMMARY

### MONITORING OBJECTIVES

Bolton Aerospace Limited operates a production of non-ferrous metals process at Ipswich which is subject to EPR Permit EP54/1/LB, under the Environmental Permitting Regulations 2010.

ESG were commissioned by Bolton Aerospace Limited to carry out stack emissions monitoring to determine the release of prescribed pollutants from the following Plant under normal operating conditions.

The results of these tests shall be used to demonstrate compliance with a set of emission limit values for prescribed pollutants as specified in the Plant's EPR Permit, EP54/1/LB.

#### **Plant**

A8 - Ball Mill

#### **Operator**

Bolton Aerospace Limited  
PO Box 22  
Hadleigh Road  
Ipswich  
Suffolk  
IP2 0EG

EPR Permit: EP54/1/LB

#### **Stack Emissions Monitoring Test House**

ESG - Cirencester Laboratory  
Unit D  
Bankside Trade Park  
Cirencester  
GL7 1YT  
UKAS and MCERTS Accreditation Number: 1015

Opinions and interpretations expressed herein are outside the scope of UKAS accreditation.  
MCERTS accredited results will only be claimed where both the sampling and analytical stages are UKAS accredited.  
This test report shall not be reproduced, except in full, without written approval of ESG.

## EXECUTIVE SUMMARY

EMISSIONS SUMMARY					
Parameter	Units	Result	Calculated Uncertainty +/-	Limit	MCERTS accredited result
Total Particulate Matter	mg/m <sup>3</sup>	0.29	0.57	20	✓
Particulate Emission Rate	g/hr	0.79	1.57	-	✓
Moisture	%	2.9	0.1	-	✓
Stack Gas Temperature	°C	31	-	-	✓
Stack Gas Velocity	m/s	17.4	0.44	-	
Gas Volumetric Flow Rate (Actual)	m <sup>3</sup> /hr	3084	160	-	
Gas Volumetric Flow Rate (STP, Wet)	m <sup>3</sup> /hr	2759	143	-	
Gas Volumetric Flow Rate (STP, Dry)	m <sup>3</sup> /hr	2680	139	-	
Gas Volumetric Flow Rate at Reference Conditions	m <sup>3</sup> /hr	2759	143	-	

ND = None Detected,

Results at or below the limit of detection are highlighted by bold italic text.

The above volumetric flow rate is calculated using data from the preliminary survey. Mass emissions for non isokinetic tests are calculated using these values. For all isokinetic testing the mass emission is calculated using test specific flow data and not the above values.

Reference conditions are 273K, 101.3kPa without correction for water vapour

## EXECUTIVE SUMMARY

MONITORING TIMES			
Parameter	Sampling Date(s)	Sampling Times	Sampling Duration
Total Particulate Matter Run 1	13 September 2016	09:14 - 10:14	60 minutes
Preliminary Stack Traverse	13 September 2016	10:16	-

## EXECUTIVE SUMMARY

### PROCESS DETAILS

Parameter	Process Details
Description of process	Production of non-ferrous metals
Continuous or batch	Batch
Product Details	Aluminium Bronze - 778 Kg
Part of batch to be monitored (if applicable)	Whole
Normal load, throughput or continuous rating	Normal Load
Fuel used during monitoring	N/A
Abatement	Bag Filter
Plume Appearance	None visible from sampling location

## EXECUTIVE SUMMARY

### Monitoring Methods

The selection of standard reference / alternative methods employed by ESG is determined, wherever possible by the hierarchy of method selection outlined in Environment Agency Technical Guidance Note (Monitoring) M2. i.e. CEN, ISO, BS, US EPA etc.

MONITORING METHODS						
Species	Method Standard Reference Method / Alternative Method	ESG Technical Procedure	UKAS Lab Number	MCERTS Accredited Method	Limit of Detection (LOD)	Calculated MU +/- %
TPM	SRM - BS EN 13284-1	AE 104	1015	Yes	0.29 mg/m <sup>3</sup>	200 %
H <sub>2</sub> O	SRM - BS EN 14790	AE 105	1015	Yes	0.01%	2.8%
Velocity	SRM - BS EN ISO 16911-1	AE 154	1015	Yes	5 Pa	2.5 %
Volumetric Flow Rate	SRM - BS EN ISO 16911-1	AE 154	1015	Yes	-	5.2 %

BS EN 14790 has been validated over a range of 4 - 40%. It is however the preferred method of the Environment Agency for concentrations below 4%

## EXECUTIVE SUMMARY

### Analytical Methods

The following tables list the analytical methods employed together with the custody and archiving details:

SAMPLING METHODS WITH SUBSEQUENT ANALYSIS							
Species	Analytical Technique	Analytical Procedure	UKAS Lab Number	UKAS Accredited Lab Analysis	Analysis Lab (ESG or Subcontract)	Sample Archive Location	Archive Period
TPM	Gravimetric	AE 106	1015	Yes	ESG - Cirencester	ESG - Cirencester	3 months
-	-	-	-	-	-	-	-

ON-SITE TESTING							
Species	Analytical Technique	Analytical Procedure	UKAS Lab Number	MCERTS Accredited Analysis	Laboratory	Data Archive Location	Archive Period
H <sub>2</sub> O	Gravimetric	AE 105	1015	Yes	ESG - Cirencester	-	-

## EXECUTIVE SUMMARY

SAMPLING LOCATION					
Sampling Plane Validation Criteria	Value	Units	Requirement	Compliant	Method
Lowest Differential Pressure	260	Pa	$\geq 5$ Pa	Yes	BS EN 15259
Lowest Gas Velocity	17.43	m/s	-	-	-
Highest Gas Velocity	17.46	m/s	-	-	-
Ratio of Gas Velocities	1.00	:1	$< 3 : 1$	Yes	BS EN 15259
Mean Velocity	17.45	m/s	-	-	-
Maximum angle of flow with regard to duct axis	$< 15$	$^{\circ}$	$< 15^{\circ}$	Yes	BS EN 15259
No local negative flow	Yes	-	-	Yes	BS EN 15259

DUCT CHARACTERISTICS		
	Value	Units
Shape	Circular	-
Depth	0.25	m
Width	-	m
Area	0.05	m <sup>2</sup>
Port Depth	90	mm

SAMPLING LINES & POINTS		
	Isokinetic	Non-Iso & Gases
Sample port size	4 " BSP	-
Number of lines used	1	-
Number of points / line	1	-
Duct orientation	Vertical	-
Filtration for TPM	QF	-

SAMPLING PLATFORM	
General Platform Information	
Permanent / Temporary Platform / Ground level / Floor Level / Roof	Temporary
Inside / Outside	Outside

M1 Platform requirements	
Is there a sufficient working area so work can be performed in a compliant manner	Yes
Platform has 2 levels of handrails (approximately 0.5 m & 1.0 m high)	Yes
Platform has vertical base boards (approximately 0.25 m high)	Yes
Platform has removable chains / self closing gates at the top of ladders	Yes
Handrail / obstructions do not hamper insertion of sampling equipment	Yes
Depth of Platform = $\geq$ Stack depth / diameter + wall and port thickness + 1.5m	No

### Sampling Platform Improvement Recommendations (if applicable)

The sampling location should meet all the requirements as specified in EA Guidance Note M1.



## EXECUTIVE SUMMARY

### **Sampling & Analytical Method Deviations**

In this instance there were no deviations from the sampling and analytical methods employed.

APPENDICES

**CONTENTS**

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

APPENDIX 3 - Measurement Uncertainty Budget Calculations

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

MONITORING SCHEDULE					
Species	Method Standard Reference Method / Alternative Method	ESG Technical Procedure	UKAS Lab Number	MCERTS Accredited Method	Number of Samples
TPM	SRM - BS EN 13284-1	AE 104	1015	Yes	1
H <sub>2</sub> O	SRM - BS EN 14790	AE 105	1015	Yes	1
Velocity	SRM - BS EN ISO 16911-1	AE 154	1015	Yes	1

APPENDIX 1 - Monitoring Schedule, Calibration Checklist & Monitoring Team

CALIBRATEABLE EQUIPMENT CHECKLIST					
Extractive Sampling		Instrumental Analyser/s		Miscellaneous	
Equipment	Equipment I.D.	Equipment	Equipment I.D.	Equipment	Equipment I.D.
Control Box DGM	P1268	Horiba PG-250 Analyser	-	Laboratory Balance	P66
Box Thermocouples	P1268	FT-IR	-	Tape Measure	P2024
Meter In Thermocouple	P1268	FT-IR Oven Box	-	Stopwatch	P2614
Meter Out Thermocouple	P1268	Bernath 3006 FID	-	Protractor	-
Control Box Timer	-	Signal 3030 FID	-	Barometer	P1916
Oven Box	-	Servomex	-	Digital Micromanometer	P1915
Probe	P1787	JCT Heated Head Filter	-	Digital Temperature Meter	P1745
Probe Thermocouple	P2277	Thermo FID	-	Stack Thermocouple	-
Probe	-	Stackmaster	-	Mass Flow Controller	-
Probe Thermocouple	-	FTIR Heater Box for Heated Line	-	MFC Display module	-
S-Pitot	P2078	Anemometer	-	1m Heated Line (1)	-
L-Pitot	-	Ecophysics NOx Analyser	-	1m Heated Line (2)	-
Site Balance	P1952	Chiller (JCT/MAK 10)	-	1m Heated Line (3)	-
Last Impinger Arm	-	Heated Line Controller (1)	-	5m Heated Line (1)	-
Dioxins Cond. Thermocouple	-	Heated Line Controller (2)	-	10m Heated Line (1)	-
Callipers	-	Site temperature Logger	-	10m Heated Line (2)	-
Small DGM	-	-	-	15m Heated Line (1)	-
Heater Controller	-	-	-	20m Heated Line (1)	-
Inclinometer (Swirl Device)	P2096	-	-	20m Heated Line (2)	-

NOTE: If the equipment I.D is represented by a dash (-), then this piece of equipment has not been used for this test.

CALIBRATION GASES					
Gas (traceable to ISO 17025)	Cylinder I.D Number	Supplier	ppm	%	Analytical Tolerance +/- %
-	-	-	-	-	-

**STACK EMISSIONS MONITORING TEAM**

Personnel	MCERTS Number	MONITORING TEAM						
		MCERTS		TE / H&S Qualifications and Expiry Date				
		Level	Expiry	TE1	TE2	TE3	TE4	H&S
Owen May	MM 10 1072	MCERTS Level 2	Feb-18	Sep-21	Jun-21	Mar-17	Mar-22	Jun-20
Jamie Whiteman	MM 16 1364	MCERTS Level 1	Jan-21	-	-	-	-	Jan-19

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

TOTAL PARTICULATE MATTER SUMMARY					
Parameter	Sampling Times	Concentration mg/m <sup>3</sup>	Uncertainty mg/m <sup>3</sup>	Limit mg/m <sup>3</sup>	Emission Rate g/hr
Run 1	09:14 - 10:14 13 September 2016	0.29	0.57	20	0.8
Blank	-	0.29	-	-	-

Reference conditions are 273K, 101.3kPa without correction for water vapour

Acetone Blank Value mg/l	Acceptable Value mg/l
2.0	10

**FILTER INFORMATION**

SAMPLES								
Test	Filter & Probe Rinse Number	Filter Start Weight	Filter End Weight	Mass Gained on Filter	Probe Rinse Start Weight	Probe Rinse End Weight	Mass Gained on Probe	Combined Total Mass Gained
Run 1	038688	0.15280	0.15270	-0.00010	68.21850	68.21880	0.00030	0.00050

If total mass gained is less than the LOD then the LOD is reported

BLANKS								
Test	Filter & Probe Number	Filter Start Weight	Filter End Weight	Mass Gained Filter	Probe Start Weight	Probe End Weight	Mass Gained Probe	Combined Total Mass Gained
Run 1	038687	0.15310	0.15290	-0.00020	71.43940	71.43960	0.00020	0.00050

If total mass gained is less than the LOD then the LOD is reported

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

ISOKINETIC SAMPLING EQUATIONS - RUN 1			TPM	
<b>Absolute pressure of stack gas, P<sub>s</sub></b>			<b>Molecular weight of dry gas, M<sub>d</sub></b>	
Barometric pressure, P <sub>b</sub>	mm Hg	757.51	CO <sub>2</sub>	% 0.03
Stack static pressure, P <sub>static</sub>	mm H <sub>2</sub> O	-7.24	O <sub>2</sub>	% 20.90
$P_s = \frac{P_b + (P_{static})}{13.6}$	mm Hg	756.98	Total	% 20.93
<b>Vol. of water vapour collected, V<sub>wstd</sub></b>			N <sub>2</sub> (100 - Total)	
Moisture trap weight increase, V <sub>lc</sub>	g	40.0	%	
$V_{wstd} = (0.001246)(V_{lc})$	m <sup>3</sup>	0.04984	M <sub>d</sub> = 0.44(%CO <sub>2</sub> ) + 0.32(%O <sub>2</sub> ) + 0.28(%N <sub>2</sub> )	
<b>Volume of gas metered dry, V<sub>mstd</sub></b>			<b>Molecular weight of wet gas, M<sub>s</sub></b>	
Volume of gas sample through gas meter, V <sub>m</sub>		1.833	M <sub>s</sub> = M <sub>d</sub> (1 - B <sub>w0</sub> ) + 18(B <sub>w0</sub> )	
Gas meter correction factor, Y <sub>d</sub>		1.0135	g/gmol 28.53	
Mean dry gas meter temperature, T <sub>m</sub>		27.958	<b>Actual flow of stack gas, Q<sub>a</sub></b>	
Mean pressure drop across orifice, DH	mmH <sub>2</sub> O	108.362	Area of stack, A <sub>s</sub>	
$V_{mstd} = \frac{(0.3592)(V_m)(P_b + (DH/13.6))(Y_d)}{T_m + 273}$		1.697	m <sup>2</sup> 0.05	
<b>Volume of gas metered wet, V<sub>mstw</sub></b>			Q <sub>a</sub> = (60)(A <sub>s</sub> )(V <sub>s</sub> )	
$V_{mstw} = V_{mstd} + V_{wstd}$	m <sup>3</sup>	1.7467	m <sup>3</sup> /min 50.9	
<b>Vol. of gas metered at O<sub>2</sub> Ref. Cond., V<sub>mstd@X%O<sub>2</sub></sub></b>			<b>Total flow of stack gas, Q</b>	
Is the process burning hazardous waste? (If yes, no favourable oxygen correction)		No	Conversion factor (K/mm.Hg)	
% oxygen measured in gas stream, act%O <sub>2</sub>		20.9	Q <sub>std</sub> = $\frac{(Q_a)P_s(0.3592)(1 - B_{w0})}{(T_s) + 273}$	
% oxygen reference condition		21	Dry 44.5	
O <sub>2</sub> Reference O <sub>2</sub> Ref = 21.0 - act%O <sub>2</sub>		No O <sub>2</sub> Ref	Q <sub>std@O<sub>2</sub></sub> = $\frac{(Q_a)P_s(0.3592)(1 - B_{w0})(O_2REF)}{(T_s) + 273}$	
Factor 21.0 - ref%O <sub>2</sub>		No O <sub>2</sub> Ref	@O <sub>2</sub> ref No O <sub>2</sub> Ref	
$V_{mstd@X\%oxygen} = (V_{mstd})(O_2 Ref)$	m <sup>3</sup>	No O <sub>2</sub> Ref	Q <sub>stw</sub> = $\frac{(Q_a)P_s(0.3592)}{(T_s) + 273}$	
<b>Moisture content, B<sub>w0</sub></b>			Wet 45.80	
$B_{w0} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	2.85	<b>Percent isokinetic, %I</b>	
<b>Moisture by FTIR</b>			Nozzle diameter, D <sub>n</sub>	
%			mm 6.22	
<b>Velocity of stack gas, V<sub>s</sub></b>			Nozzle area, A <sub>n</sub>	
Pitot tube velocity constant, K <sub>p</sub>		34.97	mm <sup>2</sup> 30.39	
Velocity pressure coefficient, C <sub>p</sub>		0.82	Total sampling time, q	
Mean of velocity heads, DP <sub>avg</sub>	mm H <sub>2</sub> O	25.96	min 60	
Mean square root of velocity heads, ÖDP		5.09	%I = $\frac{(4.6398E6)(T_s + 273)(V_{mstd})}{(P_s)(V_s)(A_n)(q)(1 - B_{w0})}$	
Mean stack gas temperature, T <sub>s</sub>	°C	29	%	
$V_s = \frac{(K_p)(C_p)(\ddot{O}DP)(\ddot{O}(T_s + 273))}{(M_s)(P_s)}$	m/s	17.28	Acceptable isokinetic range 95% to 115%	
			Yes	
<b>Moisture content, B<sub>w0</sub></b>			<b>Particulate Concentration, C</b>	
$B_{w0} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	2.85	Mass collected on filter, M <sub>f</sub>	
<b>Moisture by FTIR</b>			g -0.00010	
%			Mass collected in probe, M <sub>p</sub>	
<b>Velocity of stack gas, V<sub>s</sub></b>			g 0.00050	
Pitot tube velocity constant, K <sub>p</sub>		34.97	Total mass collected, M <sub>n</sub>	
Velocity pressure coefficient, C <sub>p</sub>		0.82	C <sub>wet</sub> = $\frac{M_n}{V_{mstw}}$	
Mean of velocity heads, DP <sub>avg</sub>	mm H <sub>2</sub> O	25.96	mg/m <sup>3</sup> 0.286	
Mean square root of velocity heads, ÖDP		5.09	C <sub>dry</sub> = $\frac{M_n}{V_{mstd}}$	
Mean stack gas temperature, T <sub>s</sub>	°C	29	mg/m <sup>3</sup> 0.295	
$V_s = \frac{(K_p)(C_p)(\ddot{O}DP)(\ddot{O}(T_s + 273))}{(M_s)(P_s)}$	m/s	17.28	C <sub>dry@X%O<sub>2</sub></sub> = $\frac{M_n}{V_{mstd@X\%oxygen}}$	
			mg/m <sup>3</sup> No O <sub>2</sub> Ref	
<b>Moisture content, B<sub>w0</sub></b>			<b>Particulate Emission Rates, E</b>	
$B_{w0} = \frac{V_{wstd}}{V_{mstd} + V_{wstd}}$	%	2.85	E = $\frac{[(C_{wet})(Q_{stw})(60)]}{1000}$	
<b>Moisture by FTIR</b>			0.79	
%				
<b>Velocity of stack gas, V<sub>s</sub></b>				
Pitot tube velocity constant, K <sub>p</sub>		34.97		
Velocity pressure coefficient, C <sub>p</sub>		0.82		
Mean of velocity heads, DP <sub>avg</sub>	mm H <sub>2</sub> O	25.96		
Mean square root of velocity heads, ÖDP		5.09		
Mean stack gas temperature, T <sub>s</sub>	°C	29		
$V_s = \frac{(K_p)(C_p)(\ddot{O}DP)(\ddot{O}(T_s + 273))}{(M_s)(P_s)}$	m/s	17.28		

As the total mass gained was less than the LOD, the LOD has been reported

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**TOTAL PARTICULATE MATTER QUALITY ASSURANCE CHECKLIST**

LEAK RATE						
Run	Mean Sampling Rate litre/min	Pre-sampling Leak Rate litre/min	Post-sampling Leak Rate litre/min	Maximum Vacuum mm Hg	Acceptable Leak Rate litre/min	Leak Tests Acceptable?
Run 1	30.96	0.16	0.2	-406.4	0.62	Yes

ISOKINETICITY		
Run	Isokinetic Variation %	Acceptable Isokineticity
Run 1	102.68	Yes

Acceptable isokinetic range 95% to 115%

WEIGHING BALANCE UNCERTAINTY			
Run	Result mg/m <sup>3</sup>	5% ELV mg/m <sup>3</sup>	LOD < 5% ELV
Run 1	0.29	1	Yes

The above is based on both the Filter and rinse uncertainty

BLANK VALUE				
Run	Overall Blank Value mg/m <sup>3</sup>	Daily Emission Limit Value mg/m <sup>3</sup>	Acceptable Blank Value mg/m <sup>3</sup>	Overall Blank Acceptable mg/m <sup>3</sup>
Blank 1	0.29	20	2.0	Yes

FILTERS					
Run	Filter Material	Filter Size mm	Max Filtration Temperature °C	Pre-use Filter Conditioning Temperature °C	Post-use Filter Conditioning Temperature °C
Run 1	QF	47	31	180	160

GF = Glass Fibre

QF = Quartz Fibre

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**MOISTURE CALCULATIONS**

Moisture Determination - Isokinetic							
Test Number	Sampling Time and Date	Start Weight	End Weight	Total gain	Concentration	LOD	Uncertainty
		kg	kg	kg	%	%	%
Run 1	09:14 - 10:14 13 September 2016	3.1071	3.1471	0.0400	2.9	0.007	2.8

Moisture Quality Assurance							
Test Number	Sampling Duration	Total Volume Sampled	Sampling Rate	Start Leak Rate	End Leak Rate	Acceptable Leak Rate	Leak Tests Acceptable?
	mins	l	l/min	l/min	l/min	l/min	
Run 1	60	1747	31.0	0.16	0.20	0.62	Yes

**PRELIMINARY STACK SURVEY**

Stack Characteristics		
Stack Diameter / Depth, D	0.25	m
Stack Width, W	-	m
Stack Area, A	0.05	m <sup>2</sup>
Average stack gas temperature	31	°C
Stack static pressure	-0.071	kPa
Barometric Pressure	101	kPa

Stack Gas Composition & Molecular Weights								
Component	Molar Mass M	Density kg/m <sup>3</sup> p	Conc Dry % Vol	Dry Volume Fraction r	Dry Conc kg/m <sup>3</sup> pi	Conc Wet % Vol	Wet Volume Fraction r	Wet Conc kg/m <sup>3</sup> pi
CO <sub>2</sub>	44	1.963059	0.030000	0.000300	0.000589	0.029144	0.000291	0.000572
O <sub>2</sub>	32	1.427679	20.900000	0.209000	0.298385	20.303652	0.203037	0.289871
N <sub>2</sub>	28	1.249219	79.070000	0.790700	0.987758	76.813865	0.768139	0.959574
H <sub>2</sub> O	18	0.803070	-	-	-	2.853339	0.028533	0.022914

Where:  $p = M / 22.41$      $pi = r \times p$

Calculation of Stack Gas Densities		
Determinand	Result	Units
Dry Density (STP), $P_{STD}$	1.2867	kg/m <sup>3</sup>
Wet Density (STP), $P_{STW}$	1.2729	kg/m <sup>3</sup>
Dry Density (Actual), $P_{Actual}$	1.1513	kg/m <sup>3</sup>
Average Wet Density (Actual), $P_{ActualW}$	1.139	kg/m <sup>3</sup>

Where:

$P_{STD}$  = sum of component concentrations, kg/m<sup>3</sup> (not including water vapour)

$P_{Actual} = P_{STD} \times (Ts / Ps) \times (Pa / Ta)$

$P_{STW} = (P_{STD} + pi \text{ of H}_2\text{O}) / (1 + (pi \text{ of H}_2\text{O} / 0.8036))$

$P_{ActualW} = P_{STW} \times (Ts / Ps) \times (Pa / Ta)$



APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY**

**TRAVERSE 1**

Date of Survey	13 September 2016
Time of Survey	10:16
Velocity Measurement Device:	S-Type Pitot

Sampling Line A								
Traverse Point	Distance into duct (m)	DP pt mmH <sub>2</sub> O (average of 3 readings)	DP pt Pa (average of 3 readings)	Temp °C	Velocity m/s	Volumetric Flow Rate (actual) m <sup>3</sup> /s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.13	26.5	260	31	17.43	0.86	-	<15
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
Mean	-	26.5	260	31	17.43	0.86	-	-

Sampling Line B								
Traverse Point	Distance into duct (m)	DP pt mmH <sub>2</sub> O (average of 3 readings)	DP pt Pa (average of 3 readings)	Temp °C	Velocity m/s	Volumetric Flow Rate (actual) m <sup>3</sup> /s	O <sub>2</sub> % Vol	Angle of Swirl °
1	0.13	26.6	261	31	17.46	0.86	-	<15
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
Mean	-	26.6	261	31	17.46	0.86	-	-

**PRELIMINARY STACK SURVEY QUALITY ASSURANCE CHECKLIST**

PITOT LEAK CHECK								
Run	Pre Traverse Leak Rate				Post Traverse Leak Rate			
	Start Value mmH <sub>2</sub> O	End Value mmH <sub>2</sub> O	Difference %	Outcome	Start Value mmH <sub>2</sub> O	End Value mmH <sub>2</sub> O	Difference %	Outcome
Run 1	90	88	2.2	Pass	92	90	2.2	Pass

To complete a compliant pitot leak check a pressure of over 80 mmH<sub>2</sub>O (or 800 Pa) is applied and the pressure drop monitored over 5 mins. A drop of ≤ 5% must be observed.

S-Type Pitot Stagnation Check				
Run	Stagnation (Pa)	Reference (Pa)	Difference (Pa)	Outcome (Permitted +/- 10 Pa)
Run 1	-71	-73	2.0	Pass

APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**PRELIMINARY STACK SURVEY (CONTINUED)**

Sampling Plane Validation Criteria				
EA Technical Guidance Note (Monitoring) M1	Result	Units	Requirement	Compliant
Lowest Differential Pressure	260.03	Pa	>= 5 Pa	Yes
Lowest Gas Velocity	17.43	m/s	-	-
Highest Gas Velocity	17.46	m/s	-	-
Ratio of Gas Velocities	1.00	-	< 3 : 1	Yes
Maximum angle of flow with regard to duct axis	0	°	< 15°	Yes
No local negative flow	Yes	-	-	Yes

Calculation of Stack Gas Velocity, V		
Velocity at Traverse Point, $V = K_{pt} \times (1-e) \times \sqrt{2 * DP_{pt} / \rho_{ActualW}}$		
<b>Where:</b>		
$K_{pt}$ = Pitot tube calibration coefficient		
(1-e) = Compressibility correction factor, assumed at a constant 0.998		
Average Stack Gas Velocity, Va	17.45	m/s

Calculation of Stack Gas Volumetric Flowrate, Q			
Duct gas flow conditions	Actual	Reference	Units
Temperature	31	0	°C
Total Pressure	100.929	101.3	kPa
Oxygen	20.9	21	%
Moisture	2.85	2.85	%
Pitot tube calibration coefficient, $K_{pt}$	0.82		

Gas Volumetric Flowrate	Result	Units
Average Stack Gas Velocity (Va)	17.45	m/s
Stack Area (A)	0.05	m <sup>2</sup>
Gas Volumetric Flowrate (Actual), $Q_{Actual}$	3084	m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Wet), $Q_{STP}$	2759	m <sup>3</sup> /hr
Gas Volumetric Flowrate (STP, Dry), $Q_{STP,Dry}$	2680	m <sup>3</sup> /hr
Gas Volumetric Flowrate (REF), $Q_{Ref}$	2759	m <sup>3</sup> /hr

**Where:**

$$Q_{Actual} = Va \times A \times 3600$$

$$Q_{STP} = Q (Actual) \times (Ts / Ta) \times (Pa / Ps) \times 3600$$

$$Q_{STP,Dry} = Q (STP) / (100 - (100 / Ma)) \times 3600$$

$$Q_{Ref} = Q (STP) \times ((100 - Ma) / (100 - Ms)) \times ((20.9 - O_{2a}) / (20.9 - O_{2s}))$$

**Nomenclature:**

Ts = Absolute Temperature, Standard Conditions, 273 K

Ps = Absolute Pressure, Standard Conditions, 101.3 kPa

Ta = Absolute Temperature, Actual Conditions, K

Pa = Absolute Pressure, Actual Conditions, kPa

Ma = Water vapour, Actual Conditions, % Vol

Ms = Water vapour, Reference Conditions, % Vol

O<sub>2a</sub> = Oxygen, Actual Conditions, % Vol

O<sub>2s</sub> = Oxygen, Reference Conditions, % Vol


APPENDIX 2 - Summaries, Calculations, Raw Data and Charts

**STACK DIAGRAM**

	Value	Units
Stack Depth	0.25	m
Stack Width	-	m
Area	0.05	m <sup>2</sup>

Non-Isokinetic/Gases Sampling			
Sampling Point	Distance (% of Depth)	Distance into Stack	Units
-	-	-	-

Isokinetic Sampling			
Sampling Point	Distance (% of Depth)	Distance into Stack (m)	Swirl °
1	50.0	0.13	< 15
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-
-	-	-	-



- Isokinetic sampling point
- Isokinetic sampling points not used
- ◐ Non Isokinetic/Gases sampling point

**SAMPLING LOCATION**



APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - TOTAL PARTICULATE MATTER**

Run	Sampled Volume m <sup>3</sup>	Sampled Gas Temp K	Sampled Gas Pressure kPa	Sampled Gas Humidity % by volume	Oxygen Content % by volume	Limit of Detection % by mass	Leak %	Uncollected Mass mg
<b>MU required</b>	≤ 2%	≤ 2%	≤ 1%	≤ 1%	≤ 10%	≤ 5% of ELV	≤ 2%	≤ 10% of ELV
Run 1	0.001	2	0.5	1	N/A	0.5000	-	-
as a %	0.06	0.66	0.50	1.00	N/A	1.43125	0.65	0.003
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>

Run	Volume (STP) m <sup>3</sup>	Mass of particulate mg	O <sub>2</sub> Correction -	Leak mg/m <sup>3</sup>	Uncollected Mass mg	Combined uncertainty
Run 1	1.58	0.5000	1.00	0.001	0.0003	-
MU as mg/m <sup>3</sup>	0.00	0.2862	-	0.001	0.0002	<b>0.29</b>
MU as %	1.30	100.0000	-	0.373	0.0577	-

<b>R1 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.57</b>	<b>mg/m<sup>3</sup></b>	<b>200.02</b>	<b>%</b>
---	-------------	-------------------------	---------------	----------

(k is a coverage factor which gives a 95% confidence in the quoted figures)

Developed for the STA by R Robinson, NPL

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - MOISTURE**

Run	Sampled Volume m <sup>3</sup>	Sampled Gas Temp K	Sampled Gas Pressure kPa	Sampled Gas Humidity % by volume	Oxygen Content % by volume	Leak %
<b>MU required</b>	<b>≤ 2%</b>	<b>≤ 2%</b>	<b>≤ 1%</b>	<b>≤ 1%</b>	<b>≤ 10%</b>	<b>≤ 2%</b>
Run 1	0.001	2	0.5	1	N/A	-
as a %	0.06	0.66	0.50	1.00	N/A	0.65
<b>compliant?</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>Yes</b>	<b>N/A</b>	<b>Yes</b>
Run	Volume (STP) m <sup>3</sup>	Mass Gained mg	O <sub>2</sub> Correction -	Leak mg/m <sup>3</sup>	Uncollected Mass mg	Combined uncertainty
Run 1	1.58	40000.00	1.00	85.42	57.74	-
MU as % v/v	0.04	0.01	-	0.01	0.004	<b>0.04</b>
MU as %	1.30	0.25	-	0.37	0.14	-

<b>R1 - Uncertainty expressed at a 95% confidence level (where k = 2)</b>	<b>0.08</b>	<b>% v/v</b>	<b>2.77</b>	<b>%</b>
---	-------------	--------------	-------------	----------

APPENDIX 3 - Measurement Uncertainty Budget Calculations

**MEASUREMENT UNCERTAINTY BUDGET - VELOCITY & VOLUMETRIC FLOW RATE**

Measured Velocity at Actual Conditions	17.4	m/s
Measured Volumetric Flow rate at Actual Conditions	3084	m <sup>3</sup> /hr

Performance Characteristics & Source of Value	Units	Values	Requirement	Compliant
<b>Uncertainty of Local Gas Velocity Determination</b>				
Uncertainty of pitot tube coefficient	-	0.010		
Uncertainty of mean local dynamic pressures	-	0.43		
Factor loading, function of the number of measurements.	3 readings	0.591	minimum 3	Yes
Range of measurement device	pa	1000		
Resolution	pa	1.00		
Calibration uncertainty	pa	5.79	<1% of Value or 20 Pa whichever is greater	Yes
Drift	% range	0.10		
Linearity	% range	0.06	<2% of value	Yes
<b>Uncertainty of gas density determination</b>				
Uncertainty of molar mass determination	kg/mol	0.00003		
Uncertainty of temperature measurement	K	1.55	<1% of value	Yes
Uncertainty of absolute pressure in the duct	pa	515		
Uncertainty associated with the estimate of density	-	0.007		
Uncertainty associated with the measurement of local velocity	-	0.0001		
Uncertainty associated with the measurement of mean velocity	-	0.0002		

Measurement Uncertainty - Velocity	m/s
Combined uncertainty	0.22
Expanded uncertainty at a 95% Confidence Interval	0.43

Note - The expanded uncertainty uses a coverage factor of k = 2.

Expanded Measurement Uncertainty of Velocity at a 95% Confidence Interval	%
Expressed as a % of the Measured Concentration	1.27
Expanded uncertainty at a 95% Confidence Interval	2.49

Measurement Uncertainty Volumetric Flow Rate	m <sup>3</sup> /hr
Combined uncertainty	81.30
Expanded uncertainty at a 95% Confidence Interval	159.34

Note - The expanded uncertainty uses a coverage factor of k = 2.

Expanded Measurement Uncertainty of Volumetric Flow Rate at a 95% Confidence Interval	%
Expressed as a % of the Measured Concentration	2.64
Expanded uncertainty at a 95% Confidence Interval	5.17

END OF REPORT